



Air Sampling Form

Client: Santa Monica Malibu USD
Project No.: SMSD-21-10154
Project Location: SAMOHI – Cafeteria bldg.
Cafeteria Area - South

Date: 5-12-21

Sample #	Sample Location	Type	Activity in Progress	Start Time	Stop Time	LPM Start	LPM Stop	Volume (L)	Fibers/Fields	F/CC*
A-1	Containment – NW	C	Clearance	1101	1516	10	10	1340	12.5/100	.005
A-2	Containment – NE	C	Clearance	1102	1518	10	10	1340	22/100	.008
A-3	Containment – Center	C	Clearance	1103	1319	10	10	1340	14.5/100	.005
A-4	Containment – SW	C	Clearance	1104	1321	10	10	1340	20/100	.007
A-5	Containment – SE	C	Clearance	1105	1323	10	10	1340	15/100	.005

Type: OWA = Outside Work Area; IWA = Inside Work Area; B = Background; P = Personal; C = Clearance

Microscopist: Randy Flores	Comments:
Microscope #: DM500	
Graticle field area (mm²): 0.00785	
Filter area (mm²): 385	
Q.C. slide readable: Yes	

On-Site Technician: Randolph Flores (#17-6028)