



1508 East 33rd Street
Signal Hill, CA 90755
Toll: 888-207-2022
Tel: 562-206-2770
Fax: 562-206-2773

Alta Environmental
3777 Long Beach Blvd.
Long Beach CA 90807
Attn.: Jim Byers

Project Number SMSD-21-10154
Project Name SAMOHI
Location Santa Monica, CA
PO Number
WO Number

Report Number 2144829

Date Received 06/23/2021
Date Analyzed 06/24/2021
Date Reported 06/24/2021

Date Sampled 06/18/2021
Sampled By Jorge Robles
Total Samples 8

Method of Analysis: NIOSH Method 7400


Test Report									
Lab ID / Customer ID	Description / Activity	Avg. Flow Rate (L/min)	Time (min.)	Volume (Liters)	Fibers Count	Fields Count	LOD (f/cc)	Results (f/mm2)	Results (f/cc)
2144829-001 0618-01	History 2nd floor, at decon	2.5	270	675	5.5	100	0.004	7.01	0.004
2144829-002 0618-02	History 2nd floor, at neg air	2.5	270	675	0.0	100	0.004	<7.0	<0.004
2144829-003 0621-01	History 2nd floor, at decon	2.0	560	1120	20.5	100	0.002	26.12	0.009
2144829-004 0621-02	History 2nd floor, at neg air	2.0	560	1120	1.0	100	0.002	<7.0	<0.002
2144829-005 0622-01	History 2nd floor, at decon	2.0	570	1140	16.0	100	0.002	20.38	0.007
2144829-006 0622-02	History 2nd floor, at neg air	2.0	570	1140	0.0	100	0.002	<7.0	<0.002
2144829-007 0622-03	BLANK Field Blank				0.0	100	NA	<7.0	NA
2144829-008 0622-04	BLANK Lab Blank				0.0	100	NA	<7.0	NA

- * All samples have been prepared and analyzed in accordance with the NIOSH 7400 method using "A" Counting Rules Issue 2, August 1994
- * OSHA PEL's are 1.0 f/cc for 30 minutes excursion and 0.1 f/cc for 8-hour Time Weighted Average (TWA).
- * Void 1= Overloaded with Fibers
- * Void 2= Overloaded with Particles
- * LOD= 5.5 fibers
- * Average Blank (f/field) = 0.000

Analyst - Justine Pablo

Approved Signatory - Cristina E. Tabatt

The limit of detection is 7 fibers/mm2. The laboratory is not responsible for data reported in fibers/cc as this data is dependent on volume collected by non-laboratory personnel. Results have been blank corrected using blanks submitted by customer or laboratory blank, as applicable. This report may not be reproduced except in full without written approval by AQ Environmental Laboratories LLC.



CHAIN OF CUSTODY

1508 E. 33rd Street
Signal Hill, CA 90755
562-206-2770 Tel
562-206-2773 Fax
services@AQenvlabs.com

(Lab) Order No. 2144829

CUSTOMER INFORMATION				Turnaround Time	Shipped By	Report Send Via:	
Company	Alta Environmental			Same Day ☐	Fedex ☐	Web ☐	
Address	3777 Long Beach Boulevard			1 Day ☒	UPS ☐	Email ☐	
City/State/Zip	Long Beach, CA 90807			2 Day ☐	USPS ☐	Fax ☐	
Contact	Jim Byers			3 Day ☐	Drop Off ☐	Verbal ☐	
Office Phone	562/ 495-5777			5 Day ☐	Drop Box ☐	Mail ☐	
Cell				Weekend ☐	Other ☐	Pick up ☐	
Fax	562/ 495-5877			Special Instructions:			
Email	Jim.Byers@AQS.com						
PROJECT INFORMATION							
Project Name:	SANTA ANITA			PO Number:			
Project Number:	2080-21-1054			Work Order No.:			
Location:	Santa Anita, CA			Sampled By:	George Roberts		
PLM		PCM		MOLD		LEAD (Pb)	
PLM EPA 600/M4-82-020	☐	NIOSH 7400A	☒	Spore Trap	☐	Air ☐	
PLM 400 Pt. Count (<0.25%)	☐	NIOSH 7400B	☐	Tape Lift	☐	Paint ☐	
PLM 1000 Pt. Count (<0.1%)	☐	w/ TWA	☐	Bulk Sample	☐	Wipe ☐	
						Soil ☐	
						TTLC ☐	
SAMPLE ID	SAMPLE TYPE	LOCATION	Date Sampled	Start Time	Stop Time	Avg Flow Rate	Volume (L)
0618-01	PLM AIR	History 2nd floor, At decon	6/18/21	1215	1645	2.5	675
0618-02		, At neg air	↓	1216	1646	2.5	675
0621-01		, At decon	6/21/21	0723	1643	2.0	1120
0621-02		, At neg air	↓	0724	1644	2.0	1120
0622-01		, At decon	6/22/21	0717	1647	2.0	1140
0622-02		, At neg air	↓	0718	1648	2.0	1140
0622-03		Field Blank	↓				
0622-04		Lab Blank	↓				
Relinquished By: [Signature]			Received By: [Signature]				
Date/Time: 6/22/21 1900			Date/Time: 6/22/21 0800				