



Air Sampling Form

Client: Santa Monica Malibu USD
Project No.: SMSD-21-10154
Project Location: SAMOHI – History Building

Date: 6-25-21

Sample #	Sample Location	Type	Activity in Progress	Start Time	Stop Time	LPM Start	LPM Stop	Volume (L)	Fibers/Fields	F/CC*
C-1	H125 – NW	C	Clearance	0726	0956	9	9	1350	21/100	.008
C-2	H125 – NE	C	Clearance	0726	0956	9	9	1350	17/100	.006
C-3	H125 – Center	C	Clearance	0726	0956	9	9	1350	15.5/100	.006
C-4	H125 – SW	C	Clearance	0726	0956	9	9	1350	18.5/100	.007
C-5	H125 – SE	C	Clearance	0726	0956	9	9	1350	13/100	.005
C-6	History 2 nd floor - North	C	Clearance	1023	1253	9	9	1350	18/100	.007
C-7	History 2 nd floor – North center	C	Clearance	1023	1253	9	9	1350	20/100	.007
C-8	History 2 nd floor - Center	C	Clearance	1023	1253	9	9	1350	16.5/100	.006
C-9	History 2 nd floor – South center	C	Clearance	1023	1253	9	9	1350	14/100	.005
C-10	History 2 nd floor - South	C	Clearance	1023	1253	9	9	1350	19/100	.007

Type: OWA = Outside Work Area; IWA = Inside Work Area; B = Background; P = Personal; C = Clearance

Microscopist: Randy Flores

Comments:

Microscope #: DM500

Graticle field area (mm²): 0.00785

Filter area (mm²): 385

Q.C. slide readable: Yes

On-Site Technician: Jorge Robles (#17-6028)