



Air Sampling Form

Client: Santa Monica Malibu USD
Project No.: SMSD-21-10154
Project Location: SAMOHI – History Building

Date: 6-28-21

Sample #	Sample Location	Type	Activity in Progress	Start Time	Stop Time	LPM Start	LPM Stop	Volume (L)	Fibers/Fields	F/CC*
C-1	H123 – NW	C	Clearance	1044	1314	9	9	1350	9.5/100	.003
C-2	H123 – NE	C	Clearance	1044	1314	9	9	1350	11/100	.004
C-3	H123 – Center	C	Clearance	1044	1314	9	9	1350	15/100	.005
C-4	H123 – SW	C	Clearance	1044	1314	9	9	1350	12/100	.004
C-5	H123 – SE	C	Clearance	1044	1314	9	9	1350	12/100	.004
C-6	Field blank									
C-7	Lab blank									

Type: OWA = Outside Work Area; IWA = Inside Work Area; B = Background; P = Personal; C = Clearance

Microscopist: Randy Flores

Comments:

Microscope #: DM500

Graticle field area (mm²): 0.00785

Filter area (mm²): 385

Q.C. slide readable: Yes

On-Site Technician: Jorge Robles (#17-6028)