



**ABATEMENT PLAN FOR REMOVAL OF  
ASBESTOS AND LEAD-BASED PAINT  
PHASE 2-HVAC**

John Adams Middle School  
2425 16<sup>th</sup> Street  
Santa Monica, CA 90405

**Prepared for:**

Santa Monica-Malibu Unified School District  
1651 Sixteenth Street  
Santa Monica, California 90404

Project No.: SMSD-18-7674  
Date: May 10, 2019

## Table of Contents

PART 1 - GENERAL.....	1
1.1 SCOPE OF WORK.....	1
1.2 WORK TO BE PERFORMED BY OTHERS.....	8
1.3 RESPONSIBILITIES OF OWNER.....	8
1.4 REQUIRED LICENSURE.....	8
1.5 PERMITS and notifications.....	9
1.6 NOTIFICATIONS.....	9
1.7 INSURANCE REQUIREMENTS.....	9
1.8 BONDING REQUIREMENTS.....	9
1.9 PROJECT SCHEDULE.....	9
1.10 APPLICABLE REGULATIONS.....	9
1.11 SUBMITTALS.....	10
1.12 NOTICES.....	11
1.13 SITE USE AND SECURITY.....	11
1.14 EMERGENCY PLANNING.....	12
1.15 FIRE PROTECTION.....	12
PART 2 - PRODUCTS.....	13
2.1 MATERIALS.....	13
2.2 EQUIPMENT.....	13
PART 3 - EXECUTION.....	14
3.1 CLEAN-UP PROCEDURES.....	14
3.2 WORKER DECONTAMINATION SYSTEMS.....	15
3.3 DISPOSAL PROCEDURES.....	15
3.4 REESTABLISHMENT OF THE WORK AREAS.....	16
3.4.1 <i>Visual Inspection</i> .....	16
3.4.2 <i>Abatement Clearance Criteria</i> .....	16
3.5 ENVIRONMENTAL MONITORING.....	17
3.6 OSHA PERSONNEL AIR MONITORING.....	17
3.7 WORK PROCEDURES.....	18
3.7.1 Minor disturbance of ACM, ACCM, LBP and lead containing paints.....	18
3.7.2 ASBESTOS-containing materials REMOVAL-TSI.....	19
3.7.3 LEAD-BASED PAINT removal- Paint Stabilization / COMPONENT REMOVAL.....	20
3.7.5 lead-containing paint construction related work.....	21

## **PART 1 - GENERAL**

The Santa Monica Malibu Unified School District will undertake an HVAC modernization project at John Adams Middle School at 2425 16<sup>th</sup> Street in Santa Monica, California.

### **1.1 SCOPE OF WORK**

The general intent of this document is to advise the Abatement Contractor of the minimum requirements for handling and removal of identified asbestos-containing materials (ACM), asbestos containing construction materials (ACCM), lead-based paint (LBP), and lead containing materials which will be impacted by the upcoming HVAC project at the Project Site.

Alternative procedures may be used; however, alternative procedures must meet or exceed current federal, state, local and District specification requirements. Alternative procedures must be reviewed and approved by District representatives prior to implementation of the work.

An asbestos and lead survey has been prepared for this site by Alta Environmental (#SMSD-18-7674). The survey report should be used in conjunction with this Plan to confirm the presence of asbestos and lead in paint that are in the areas impacted by the project. Quantities, if provided, should be field verified by the Abatement Contractor.

By submitting a bid, the Abatement Contractor warrants its intent to conduct said work properly using qualified personnel employed by licensed contractors.

- A. Removal scope of work shall include all impacted materials listed in the Tables 1.1.1, 1.1.2, 1.1.3, listed below.
- B. All removal and disturbance of asbestos-containing materials and asbestos containing construction materials and their subsequent waste shall be performed by an asbestos Abatement Contractor, using 40-hour asbestos trained workers (Asbestos Worker trained as outlined in 40 CFR 763). The Abatement Contractor's workforce shall be supervised by experienced trained workers, knowledgeable and qualified in the techniques of asbestos abatement, in handling and disposing of asbestos-containing and/or asbestos-contaminated materials, and in the subsequent cleaning of contaminated areas. The Abatement Contractor's workforce, at a minimum should be Competent Person/Contractor Supervisor trained outlined in 40 CFR 763.
- C. As indicated in Table 1.1.1 certain materials were found to be damaged and associated asbestos containing debris was observed to be present upon an initial survey. As indicated in Table 1.1.1, an SCAQMD Procedure 5 Work Plan will be required. In general, this will require fully containing the work area, establishing a negative pressure enclosure, removing the asbestos containing debris, and decontaminating all surfaces by wet-wiping and HEPA vacuuming followed by the application of an encapsulant. This work may require scheduling during off school times including vacation/break times.
- D. All removal and disturbance of lead-based paints and subsequent waste disposal shall be performed by a state-licensed contractor, using CDPH-certified workers with at least one CDPH-certified Supervisor. The Abatement Contractor's workforce shall be supervised by experienced trained workers, knowledgeable and qualified in the techniques of lead abatement, in handling and disposing of lead-containing and/or lead-contaminated materials, and in the subsequent cleaning of contaminated areas.
- E. All removal and disturbances of lead containing painted surfaces (reported as detected to 5,000 ppm by paint chip analysis) are subject to Cal/OSHA requirements as set forth in (8 CCR 1532.1) including training and the use of respirators and protective clothing.

Respirators and protective clothing must be utilized until the Contractor has demonstrated, through objective data, the exposure levels to lead dust (based on a negative exposure assessment) do not exceed the permissible exposure level.

- F. When exposure monitoring of a lead-related task indicates that the permissible exposure level is or will be exceeded, the Contractor shall use CDPH-certified lead workers to complete the task.
- G. Material quantities included in this report are provided as an estimate only and are for information only and shall not be used as a reliable quantity for preparing removal bids. The Contractor shall be solely responsible for assessing the type, extent, and quantity of material to be removed in each area of the project when preparing each project bid. Estimated quantities listed in this report were based on observed material in areas impacted by the scope of work.
- H. The Abatement Contractor shall furnish all labor, materials, services, and insurance. Insurance specifically covers the handling and transportation of ACMs and LBP which is specified, shown, or reasonably implied for the removal, transport, and disposal of the hazardous materials identified in Tables 1.1.1, 1.1.2, 1.1.3 listed below.

**Table 1.1.1-SUMMARY OF ASBESTOS-CONTAINING MATERIALS  
BUILDING A**

<b>MATERIAL</b>	<b>LOCATION</b>	<b>SCOPE OF IMPACT</b>	<b>SECTION</b>
Rough plaster	93A, janitors' closet, heater closet	Minor impact in areas impacted by the project drawings and specifications	3.7.1
Gypsum board with joint compound	Under 12"x12" random peg hole wall/ceiling tile and throughout all rooms except restrooms, janitor's closets, ceilings in 94A, B, C. All ceilings throughout	Minor impact in areas impacted by the project drawings and specifications	3.7.1
Hard pipe fitting TSI	Room 95	Potential for impact in areas impacted by the project drawings and specifications	3.7.2 (Glove Bag-SCAQMD Procedure 2)
Stucco	Exterior walls	Minor impact in areas impacted by the project drawings and specifications	3.7.1

**SPACE INTENTIONALLY LEFT BLANK**

<b>BUILDING B</b>			
<b>MATERIAL</b>	<b>LOCATION</b>	<b>SCOPE OF IMPACT</b>	<b>SECTION</b>
Silver roof mastic	Roof penetrations, pads, patches, and wood block	Minor impact in areas impacted by the project drawings and specifications	3.7.1 SCAQMD Procedure 3
1'x1' random large and small peg hole ceiling tile with mastic	Serving area, kitchen, eating area 2	Minor impact in areas impacted by the project drawings and specifications	3.7.1
Cement asbestos access panels (2'x4')	Hallway west and east ceiling	Minor impact in areas impacted by the project drawings and specifications	3.7.1
10" O.D. Transite Pipe	Visible at Roof – east end of roof	Potential impact in areas impacted by the project drawings and specifications	3.7.1- SCAQMD Procedure 3

<b>Building C Gymnasium Building</b>			
<b>MATERIAL</b>	<b>LOCATION</b>	<b>SCOPE OF IMPACT</b>	<b>SECTION</b>
Acoustical plaster ceiling	Rooms 102, 106, 113, 114 lounge storage room (under ceiling tiles)	Potential impact in areas impacted by the project drawings and specifications	3.7.1
8" oval Transite pipe	Room 196 (attic space thru roof)	Potential impact in areas impacted by the project drawings and specifications	3.7.1

<b>BUILDINGS E, F, and G</b>			
<b>MATERIAL</b>	<b>LOCATION</b>	<b>SCOPE OF IMPACT</b>	<b>SECTION</b>
No ACMs or ACCMs Were Identified			

**SPACE INTENTIONALLY LEFT BLANK**

<b>BUILDING P/N</b>			
<b>MATERIAL</b>	<b>LOCATION</b>	<b>SCOPE OF IMPACT</b>	<b>SECTION</b>
4" O. D. white TSI	Ceiling spaces above Room 44, 45, 47	Potential impact in areas impacted by the project drawings and specifications	3.7.2-SCAQMD Procedure 3
Acoustical plaster (ceiling)	54-57, 47,47A, 45,44	Minor impact in areas impacted by the project drawings and specifications	3.7.1
Stucco	Exterior walls and sections of ceiling	Minor impact in areas impacted by the project drawings and specifications	3.7.1

<b>BUILDING Q</b>			
<b>MATERIAL</b>	<b>LOCATION</b>	<b>SCOPE OF IMPACT</b>	<b>SECTION</b>
Acoustical plaster ceiling	Above 12X12 pin-hole ceiling tiles in Room 29	Minor impact in areas impacted by the project drawings and specifications	3.7.1
	Above 2x4 drop ceiling in Rooms 15, 28, 29, and 34-debris present on ceiling panels		
	Above wood paneling in Room 15		
Acoustical plaster ceiling debris	Above 2x4 drop ceiling in Rooms 15, 28, 29, and 34-debris present on ceiling panels	Will Require SCAQMD P5	SCAQMD P5
1'x1' random pinhole ceiling tile with mastic	Room 32, mechanical room 2	Minor impact in areas impacted by the project drawings and specifications	3.7.1

<b>BUILDING S</b>			
<b>MATERIAL</b>	<b>LOCATION</b>	<b>SCOPE OF IMPACT</b>	<b>SECTION</b>
Acoustical plaster ceiling	Rooms, 50-53, 52 A&B	Minor impact in areas impacted by the project drawings and specifications	3.7.1

<b>BUILDING T</b>			
<b>MATERIAL</b>	<b>LOCATION</b>	<b>SCOPE OF IMPACT</b>	<b>SECTION</b>
Gypsum board with joint compound	Rooms T04, Mech space above T04 RR, T03, Janitors office, community liaison, T102, T103, T01 (walls, sections of ceilings)	Minor impact in areas impacted by the project drawings and specifications	3.7.1
Joint Compound (Confirmation samples)	Rooms T04, Mech space above T04 RR, T03, Janitors office, community liaison, T102, T103, T01 (walls, sections of ceilings)	Minor impact in areas impacted by the project drawings and specifications	3.7.1
Drywall (Confirmation sample)	Rooms T04, Mech space above T04 RR, T03, Janitors office, community liaison, T102, T103, T01 (walls, sections of ceilings)	Minor impact in areas impacted by the project drawings and specifications	3.7.1
Composite-drywall with joint compound (Confirmation sample)	Rooms T04, Mech space above T04 RR, T03, Janitors office, community liaison, T102, T103, T01 (walls, sections of ceilings)	Minor impact in areas impacted by the project drawings and specifications	3.7.1
Acoustical plaster ceiling	Room 19, Room 19 Storage Room 21 (Above fissured ceiling tiles) Room 22A Room 23 Room T158	Minor impact in areas impacted by the project drawings and specifications	3.7.1
Acoustical plaster ceiling debris	Room 30 Room 31 Room T04 Room T04A Room T101 Room T102 Room T103 Room T137 Room T139	Will require SCAQMD P5	P5
Acoustical wall plaster	Room T101 under wall tile	Minor impact in areas impacted by the project drawings and specifications	3.7.1
Light weight concrete	Room T04 mech space above restroom	Potential impact in areas impacted by the project drawings and specifications	3.7.1

**Table 1.1.2- SUMMARY OF LEAD-BASED PAINT**

**BUILDING A**

<b>COMPONENT</b>	<b>LOCATION</b>	<b>SCOPE OF IMPACT/ESTIMATED</b>	<b>SECTION</b>
Dust Collector/Cyclone	Roof	Whole component removal	3.7.3

**BUILDING B**

<b>COMPONENT</b>	<b>LOCATION</b>	<b>SCOPE OF IMPACT/ESTIMATED</b>	<b>SECTION</b>
Wall-drywall-white	Interior walls throughout patch work	Minor impact in areas impacted by the project drawings and specifications	3.7.1
Window case-wood-white	Interior and exterior original wood windows	Minor impact in areas impacted by the project drawings and specifications	3.7.1

**SPACE INTENTIONALLY LEFT BLANK**



<b>Gymnasium Building</b>			
<b>COMPONENT</b>	<b>LOCATION</b>	<b>SCOPE OF IMPACT/ESTIMATED</b>	<b>SECTION</b>
Door casings-wood-white	Interior all door casings	Minor impact in areas impacted by the project drawings and specifications	3.7.1
Door-metal-green	Mechanical room, boy's restrooms, girl's restroom, hallway B, C, room 111	Minor impact in areas impacted by the project drawings and specifications	3.7.1
Window casing-wood-white	Interior/exterior, original windows, also frames remains around new replacement aluminum window	Minor impact in areas impacted by the project drawings and specifications	3.7.1
Hatch-wood-white	Hallway B	Minor impact in areas impacted by the project drawings and specifications	3.7.1
Door and door casings-wood-green	All exterior wood doors and door casings	Minor impact in areas impacted by the project drawings and specifications	3.7.1
Fascia board-wood-green	All exterior fascia boards	Minor impact in areas impacted by the project drawings and specifications	3.7.1
Wall, wall trim and baseboard-ceramic-brown and white	Boys locker room	Minor impact in areas impacted by the project drawings and specifications	3.7.1
Wall-ceramic-brown and yellow	Storage room B (in boy's locker room)	Minor impact in areas impacted by the project drawings and specifications	3.7.1
Wall-ceramic-grey	Boys restroom, girl's restroom, hallway, room 102 restroom, room 113 restroom	Minor impact in areas impacted by the project drawings and specifications	3.7.1

<b>BUILDINGS E, F, and G</b>			
<b>MATERIAL</b>	<b>LOCATION</b>	<b>SCOPE OF IMPACT</b>	<b>SECTION</b>
No Suspect Materials Identified			

<b>BUILDING P</b>			
<b>COMPONENT</b>	<b>LOCATION</b>	<b>SCOPE OF IMPACT/ESTIMATED</b>	<b>SECTION</b>
Flashing-metal-green	Exterior north center	Minor impact in areas impacted by the project drawings and specifications	3.7.1

<b>BUILDING Q</b>			
<b>COMPONENT</b>	<b>LOCATION</b>	<b>SCOPE OF IMPACT/ESTIMATED</b>	<b>SECTION</b>
Wall-stucco-white	Exterior walls	Minor impact in areas impacted by the project drawings and specifications	3.7.1
Flashing-metal-green	Exterior	Minor impact in areas impacted by the project drawings and specifications	3.7.1

<b>BUILDING T</b>			
<b>COMPONENT</b>	<b>LOCATION</b>	<b>SCOPE OF IMPACT/ESTIMATED</b>	<b>SECTION</b>
Flashing-metal-green	Exterior wall	Minor impact in areas impacted by the project drawings and specifications	3.7.1
Window casing-wood-green	Interior and Exterior	Minor impact in areas impacted by the project drawings and specifications	3.7.1

<b>Table 1.1.3-SUMMARY OF LEAD-CONTAINING PAINT</b>	
All removal and disturbances of lead containing painted surfaces (reported as greater than detection level and 5,000 ppm by paint chip analysis) are subject to Cal/OSHA worker exposure requirements (8 CCR 1532.1) including the use of respirators and protective clothing until the Contractor has demonstrated, through objective data, the exposure levels to lead dust (based on a negative exposure assessment) do not exceed the permissible exposure level.	3.7.1

## **1.2 WORK TO BE PERFORMED BY OTHERS**

- A. As per Project Drawings.

## **1.3 RESPONSIBILITIES OF OWNER**

- A. The Owner may elect to provide daily oversight and environmental monitoring surrounding the abatement/removal operations.

## **1.4 REQUIRED LICENSURE**

- A. Abatement Contractor shall be licensed by the State of California Contractors State License Board and be registered to perform asbestos related work with the Division of Occupational Safety and Health, Department of Industrial Relations. At a minimum, the Abatement Contractor shall hold the following license classification:
  1. ASB - Asbestos Certification

- 2. U.S. EPA Renovation, Repair, & Repainting Program (RRRP), if required
- B. Transportation of Friable and Non-Friable Asbestos Containing Materials: Contractor shall be or have a subcontractor who is a registered hazardous waste transporter with the State of California, Department of Toxic Substances Control.
- C. Subcontractors shall hold all licenses applicable to specified trade work.

**1.5 PERMITS AND NOTIFICATIONS**

- A. As required by California Division of Occupational Safety and Health (Cal/OSHA)
- B. As required by the South Coast Air Quality Management District (SCAQMD)
- C. As required by Department of Health Services (Cal/DPH)
- D. As required by local agencies for specific tasks (i.e., temporary power, etc.)

**1.6 NOTIFICATIONS**

- A. Contractor shall make all required written notifications to regulatory agencies including the following:
  - 1. Cal/OSHA
  - 2. SCAQMD
  - 3. Cal/DPH, if required.

**1.7 INSURANCE REQUIREMENTS**

- A. Provide as per Project Specifications.

**1.8 BONDING REQUIREMENTS**

- A. Provide as per Project Specifications.

**1.9 PROJECT SCHEDULE**

- A. Project Start Date: As specified by owner  
Project Completion Date: As specified by owner
- B. All work shall be performed as per agreement between Contractor and Owner.

**1.10 APPLICABLE REGULATIONS**

- A. Contractor shall perform all work in compliance with current, applicable federal, state, and local regulations, standards, and codes including District specifications governing asbestos abatement, transport, and disposal of asbestos containing/contaminated materials, of lead-based/containing surface coatings and contaminated materials, and of all other hazardous materials.
  - 1. Requirements include obtaining permits, licenses, inspections, releases and similar documentation as well as payments, statements, and similar requirements associated with codes, regulations, and standards.
- B. Regulations, Standards, and Codes (General):
  - 1. General applicability of federal, state, and local regulations, standards, and codes governing hazardous materials abatement, demolition, transport, and disposal, except to the extent that more explicit or more stringent requirements

are written directly into the contract documents. All applicable regulations, standards, and codes have the same force and effect and are made a part of the contract documents as if copied directly into the contract documents, or as if published copies are bound herewith.

- C. Contractor Responsibility: The Contractor shall assume full responsibility and liability for the compliance with all applicable federal, state, and local regulations including District Specifications pertaining to work practices, transport, disposal, and protection of workers, visitors to the site, and persons occupying areas adjacent to the site.
1. The Contractor is responsible for providing training, medical examinations and maintaining training/medical records of personnel as required by the applicable federal, state, and local regulations.
  2. The Contractor shall hold the Owner and Project Environmental Consultant harmless for failure to comply with any applicable hazardous materials abatement, transport, disposal, safety, health, or other regulation on the part of himself/herself, his/her employees, or his/her subcontractors.

### **1.11 SUBMITTALS**

- A. Prior to commencement of work, the Abatement Contractor shall submit to the Project Environmental Consultant (Owner's Representative) documentation that includes, without limitation, the following:
1. Copies of licenses and registrations required by Article 1.6 Required Licensure (includes copies of subcontractors' licenses).
  2. Copies of written notifications to the following regulatory agencies:
    - a. Cal/OSHA
    - b. SCAQMD
    - c. Cal/DPH, if necessary.
  3. Manufacturer's certification that HEPA vacuums, differential pressure air filtration devices, and other local exhaust ventilation equipment conform to ANSI Z9.2-79 and have been permitted by the SCAQMD.
  4. Documentation showing that Contractor's employees, including foreman, supervisors, and any other company personnel or agents who may be exposed to airborne asbestos fibers or who may be responsible for any aspects of asbestos abatement activities, have received training as required by 29 CFR 1926.1101 and 8 CCR 1529.
  5. Documentation showing that Contractor's employees, including foreman, supervisors, and any other company personnel or agents who may be exposed to airborne lead dust or who may be responsible for any aspects of lead abatement activities, have received training as required by 29 CFR 1926.62 and 8 CCR 1532.1.
  6. Documentation from Physician (signed by an M.D.) showing that all employees or agents who may be exposed to airborne asbestos fibers in excess of background levels have received medical monitoring to determine whether they are physically capable of working while wearing a respirator without suffering from adverse health effects. The Contractor must be aware of and provide information to the examining physician about unusual conditions in the workplace environment (e.g. high temperatures, humidity, and chemical contaminants) that may impact the employee's ability to perform work activities.
  7. Documentation of respirator fit-testing for all Contractor employees and agents who must enter the work area. This fit-testing shall be conducted annually and in

accordance with procedures as required by 29 CFR 1910.134 and 8 CCR 5144.

8. An emergency preparedness plan as required by Article 1.16 - Emergency Planning.
- B. During abatement activities, the Abatement Contractor shall maintain on-site records and submit to the Project Environmental Consultant at the completion of the project documentation that includes, without limitation, the following:
1. Copies of the work area entry/exit log book.
  2. Copies of logs documenting filter changes on respirators, HEPA vacuums, differential pressure air filtration devices, water filtration devices, and other engineering controls.
  3. Copies of Material Safety Data Sheets (MSDS) for solvents, encapsulants, wetting agents, replacement materials, and other substances brought by the Contractor to the Project Site. MSDSs shall be available the first day that subject materials/substances are present on the project site.
  4. Results of all required OSHA compliance air monitoring. Results shall be available for review by Consultant and Owner within 24 hours of the sampling.
  5. Copies of all accident/incident reports where injury or damage has occurred on or to the Owner's property.
  6. Copies of daily logs indicating location(s) worked, type(s) of materials removed, Quantity(s) of materials removed, and number of personnel conducting the aforementioned activities.
  7. Copies of all transport manifests, trip tickets, and disposal receipts for all asbestos waste materials removed from the site.

### **1.12 NOTICES**

- A. Post in the clean room area of the worker decontamination enclosure a list containing the names, and telephone numbers of Owner, Construction Manager, Abatement Contractor, and Project Environmental Consultant.
- B. Additional postings shall include:
1. Visitor Entry and Exit Log.
  2. Employee Daily Sign in Log.
  3. Entry and Exit Procedures.
  4. Emergency Procedures.
  5. Copies of permits required in Article 1.7 of this document and copies of notifications required in Article 1.8 of this document.
  6. As required by the Department of Labor.

### **1.13 SITE USE AND SECURITY**

- A. Confine operations at the site to the areas permitted under the Contract. Portions of the site beyond areas on which work is indicated are not to be disturbed.
- B. The work area shall be restricted only to authorized, trained, and protected personnel

including the Abatement Contractor, Abatement Contractor's employees, Owner's employees, Owner, Construction Manager, Project Environmental Consultant, and State and Local Inspectors.

- C. Entry into the work area by unauthorized individuals shall be reported immediately to the Project Environmental Consultant.
- D. Contractor shall be responsible for Project site security during abatement operations.

#### **1.14 EMERGENCY PLANNING**

- A. Emergency planning and procedures shall be developed by the Abatement Contractor prior to abatement initiation.
- B. Emergency procedures shall be in written form and prominently posted. Contractor shall ensure that all persons entering the work area read these procedures and understand the Project Site layout, location of emergency exits and emergency procedures.
- C. Emergency planning shall include considerations of fire, explosion, electrical hazards, slips, trips and falls, confined spaces, and heat related injuries. Written procedures shall be developed and employee training in procedures shall be provided by the Contractor.
- D. Employees shall be trained in evacuation procedures in the event of work place emergencies.
  - 1. For non-life-threatening situations, employees injured or otherwise incapacitated shall decontaminate following normal procedures with assistance from fellow workers, if necessary, before exiting the work place to obtain proper medical treatment.
  - 2. For life threatening injury or illness, worker decontamination shall take least priority. After measures to stabilize the injured worker, remove him/her from the work place and secure proper medical treatment.
  - 3. Telephone numbers of all emergency response personnel shall be prominently posted in the clean and equipment rooms.

#### **1.15 FIRE PROTECTION**

- A. All plastic, spray-on strippable coatings, and structural materials used in the asbestos abatement processes shall be UL-approved and certified as fire retardant or noncombustible.
- B. Wood shall be pressure impregnated and certified as fire retardant.
- C. Safety Data Sheets (SDS) for fire retardant materials shall be made available upon request.
- D. All combustible rubbish and debris, including asbestos waste shall be properly packaged, labeled, and stored in a District designated lockable storage facility at the end of each workday.
- E. A minimum of one (1) 4A/60BC dry-chemical extinguisher shall be maintained at each of the following locations:
  - 1. At each corner of the work area. Where no clear corners exist, four (4)

extinguishers shall be placed around the exterior wall of the work area so that they are approximately 25 percent of the total distance apart.

- a. Exception: Where the total contained work area is less than 1,000 square feet, two (2) 4A/60BC extinguishers shall be provided. All extinguishers shall be clearly identified with red tape.
- 2. Contractor shall ensure that on site personnel are aware of the location and proper use of all extinguishers and other fire/life safety equipment.
- F. All existing fire detection, alarm systems, connections and standpipes shall remain in place, active, and unobstructed. Any alteration to this equipment must be approved by the Owner.

## **PART 2 - PRODUCTS**

### **2.1 MATERIALS**

- A. Generally, Contractor shall carefully adhere to the following:
  - 1. All plastic, spray-on strippable coatings, and structural materials used shall be UL-certified as fire retardant or non-combustible.
  - 2. Fire-retardant polyethylene sheeting utilized for worker decontamination and construction/containment barriers shall be a minimum of six-mil in thickness.
  - 3. Disposal bags used to package hazardous waste shall be of six-mil polyethylene, pre-printed with labels as required by EPA regulation 40 CFR 61.152 (b) and 8 CCR 1529.
  - 4. Warning signs as required by Cal/OSHA shall be utilized.
- B. Removal and Encapsulation:
  - 1. Apply surfactant during removal work activities.
  - 2. Apply an encapsulating agent to the substrate surfaces from which asbestos-containing material has been stripped.
  - 3. Mastic removal solvents shall be of the low odor variety.

### **2.2 EQUIPMENT**

- A. General:
  - 1. A sufficient quantity of HEPA vacuums and/or differential pressure air filtration devices equipped with HEPA filtration shall be used to control asbestos fibers during the removal of asbestos containing materials. To calculate total air flow requirement:

$$\text{Total ft}^3/\text{min} = \frac{\text{Vol. of work area (in ft}^3\text{)}}{15 \text{ min}}$$

To calculate the number of units needed for the abatement:

$$\text{Number of units needed} = \frac{[\text{total ft}^3/\text{min}]}{[\text{capacity of unit in ft}^3/\text{min}]}$$

2. At a minimum, full-face powered air-purifying respirators (PAPRs) equipped with HEPA filter cartridges shall be utilized during all friable/Class I asbestos removal and for all removal of lead-containing paints/substances involving abrasive removal techniques.
  3. At a minimum, half-face air-purifying respirators with P-100 cartridges shall be utilized for the removal of all non-friable/Class II asbestos, lead coated ceramic tile, and impacted/damaged lead-based paint. This does not apply to abrasive removal.
  4. Respirators shall be furnished to the abatement workers by the Abatement Contractor. The respirators shall have been tested and approved by the National Institute of Occupational Safety and Health (NIOSH) for use in asbestos-contaminated atmospheres.
  5. Full body disposable protective clothing, including head, body, and foot coverings shall be furnished to workers and visitors by the Abatement Contractor. The clothing shall include adequate sizes to accommodate movement without tearing.
  6. Additional safety equipment as supplied in accordance with 8 CCR 1514, (e.g. hard hats meeting the requirements of 8 CCR 1515, eye protection meeting the requirements of 8 CCR 1516, safety shoes meeting the requirements of 8 CCR 1517, hand protection meeting the requirements of 8 CCR 1520, hearing protection meeting the requirements of 8 CCR 1521, and body protection meeting the requirements of 8 CCR 1522), as necessary, shall be furnished to all workers and authorized visitors.
- B. Removal:
1. Removal shall be performed using manual means and methods. Perform removal in manageable sections and perform continuous clean-up of debris. Mechanical removal shall only be performed in conjunction with Owner approved HEPA air filtration systems.
  2. Perform detail cleaning using HEPA vacuuming and wet wiping methods. No brooms shall be used during asbestos and lead-based paint related work.
- C. Encapsulation: Encapsulants shall be sprayed using airless spray equipment or hand pressurized sprayer.

## **PART 3 - EXECUTION**

### **3.1 CLEAN-UP PROCEDURES**

- A. Remove and containerize all visible accumulations of asbestos-containing material, and asbestos/lead-contaminated debris utilizing rubber dust pans and rubber squeegees to move material around. Do not use metal shovels to pick up or move accumulated waste within contained work areas.

Asbestos-containing/contaminated waste shall be packaged and label in accordance with



EPA regulation 40 CFR 61.152 (b) (I) (iv), Cal/OSHA (Title 8 CCR Sections 1529 and 5208), SCAQMD Rule 1403, and if applicable Title 22 CCR Section 66504.

Lead-waste wastes shall be packaged, and label as required by 8 CCR 1532.1 and 22 CCR 66504.

All other hazardous wastes shall be containerized as appropriate and disposed of in a manner that satisfies the requirements for waste characterization and disposal in accordance with the requirements of Title 22 of the California Code of Regulations, Sections 66243, et seq., and Sections 25157.8, et al, of the California Health and Safety Code.

- B. Whether cleaning an asbestos work area or a lead work area (or both), wet clean all surfaces in the work area using a HEPA-vacuum, as appropriate.
- C. After gross cleaning of the work area, HEPA-vacuum and wet clean all objects and surfaces in the work area are completed, remove all containerized waste from the work area.
- D. Decontaminate all tools and equipment and remove at the appropriate time in the cleaning sequence.
- E. Project Environmental Consultant and the Abatement Contractor representative will inspect the work area for visible residue. If any accumulation of residue is observed, a second settling period and cleaning cycle will be repeated at no additional cost to the Owner.
- F. Following the satisfactory completion of clearance air monitoring or clearance wipe testing, the remaining barriers may be removed and prepared for proper disposal. A final visual inspection by Project Environmental Consultant and the Abatement Contractor representative will be performed. Unsatisfactory conditions may require additional cleaning and air monitoring/wipe sampling, at no additional cost to the Owner.

### **3.2 WORKER DECONTAMINATION SYSTEMS**

- A. Worker decontamination enclosure systems shall be provided at all locations where workers will enter or exit regulated work areas.
- B. Worker decontamination enclosure systems constructed at the Project Site shall utilize six-mil, fire-retardant polyethylene sheeting, or other approved materials for privacy.
- C. Personnel Decontamination Units shall not be located inside the work area(s) unless specifically authorized by the Project Environmental Consultant.
- D. Alternative methods of providing decontamination facilities may be submitted to the Project Environmental Consultant for approval. Do not proceed with any such method(s) without the written authorization.
- E. The worker decontamination enclosure system shall consist of at least a cleansing station in accordance with the requirements of 8 CCR 1527 and 8 CCR 1529, equipped with adequate water, towels, and cleansing agents to accommodate the entire crew and visitors.

### **3.3 DISPOSAL PROCEDURES**

- A. All Class I friable asbestos waste shall be disposed as hazardous waste and disposed of at an appropriate landfill facility. The waste shall be manifested using a Uniform Hazardous Waste Manifest.

- B. All Class II non-friable asbestos waste shall be disposed of as Non-Hazardous, Non-Friable Asbestos Waste. A non-hazardous material data form will be required.
- C. All asbestos-containing waste shall be placed and stored in clear, sealed, leak-tight, and appropriately labeled containers in accordance with 8 CCR 1529 and SCAQMD Rule 1403, and be transported to an appropriate landfill for disposal.
- D. The Abatement Contractor will be responsible for segregating lead waste (LBP and LCP) into separate waste streams. The Contractor will be required to collect a sufficient number of samples to adequately characterize the waste stream. Sample analysis will include at a minimum, Total Threshold Limit Concentration (TTLC), Soluble Threshold Limit Concentration (STLC), and Toxicity Characteristic Leaching Procedure (TCLP).  
  
The Contractor shall develop and submit for review a waste sampling and management plan to the Owner and the Project Environmental Consultant.
- E. All hazardous wastes (including non-hazardous asbestos wastes) must be transported by a certified waste hauler and disposed off at a waste facility approved by the Owner.
- F. Obtain the EPA Hazardous Waste Generator Identification Number and State of California Hazardous Waste Tax Identification Number from the Owner for hazardous waste disposal.
- G. All hazardous waste manifests or non-hazardous material data forms shall be delivered to the Owner. Record keeping format shall utilize a chain of custody form which includes the names and addresses of the Generator (Owner), Contractor, Waste Hauler, pickup site, disposal site, the estimated quantity of the asbestos waste and the type of containers used. The form shall be signed by the Generator, Contractor, Waste Hauler and the Disposal Site Operator, as the responsibility for the material changes hands.

### **3.4 REESTABLISHMENT OF THE WORK AREAS**

#### **3.4.1 VISUAL INSPECTION**

Upon completion of the removal process, the Owner representative and the Abatement Contractor will conduct a post-abatement visual inspection. If any material designated for removal, including loose debris, is observed the Contractor will be required to re-clean that specific area.

#### **3.4.2 ABATEMENT CLEARANCE CRITERIA**

1. Following the completion of final clean-up operations, Project Environmental Consultant will be notified that work areas are ready for final inspection and clearance air monitoring.
  - a. Project Environmental Consultant will then sample the air in the work area for airborne fiber concentrations.
  - b. Samples from removal areas with less than 160 square feet of removed material, at the discretion of the District, will be analyzed using Phase Contrast Microscopy (PCM) utilizing the NIOSH 7400 method. A minimum of five samples from inside the work area will be collected. Clearance will be issued when all samples results show that the airborne fiber concentrations inside the abatement work area are equal to or less than 0.01 f/cc or the background level (whichever is greater).
  - c. Samples from removal areas with greater than 160 square feet or 260 linear feet of removed material, will be analyzed using Transmission Electron Microscopy (TEM). A minimum of five samples from inside the work area will be collected. If the arithmetic mean of their asbestos

structure concentrations per square millimeter is less than or equal to 70 structures per square millimeter, the asbestos removal and clean-up activities within the work area will be deemed to have been completed.

- d. If these conditions are not met, decontamination shall be deemed incomplete and the cleaning procedures shall be repeated. The area shall be re-cleaned and re-tested at no additional cost to the Owner until satisfactory levels are obtained.
2. For lead-based removal work, wipe sampling shall be performed within the controlled work areas following completion of demotion work.
    - a) Release Criteria: Decontamination of the work area is complete when at least one representative sample per work area is analyzed and reveals lead concentrations below 40 micrograms of lead per square foot of area on interior floors, 250 micrograms of lead per square foot of area on window channels/sills, and 800 micrograms of lead per square foot of area on exterior floors.
    - b) If these conditions are not met, then the decontamination is incomplete, and the cleaning procedures noted in Article 3.1 above shall be repeated. The area shall be re-tested at no additional cost to the Owner until satisfactory levels are obtained.
    - c) For removal/demolition of lead-based paint components where the component was removed intact and without creating a disturbance to the LBP, clearance will be issued upon passing of a final visual inspection completed as described in section 3.4.1 of this work plan.

### **3.5 ENVIRONMENTAL MONITORING**

Air monitoring will be carried out by the Project Environmental Consultant on behalf of the Owner to verify that the building beyond the contamination area and the outside environment remains uncontaminated.

Area Air Monitoring: The Project Environmental Consultant will conduct in-progress air monitoring daily to determine area airborne contaminant concentrations within the confines of the work area.

Environmental Air Sampling: Ambient air samples will be collected and analyzed to indicate fiber migration from containment to the environment. Should any environmental sample outside work areas exceed the base line of 0.01 f/cc of air or established background concentrations as determined by PCM analysis, all work will immediately halt except for corrective work. The PEC shall determine the source of the high fiber count and notify the Contractor with directions for the corrective action.

### **3.6 OSHA PERSONNEL AIR MONITORING**

Air monitoring required by Cal/OSHA is the responsibility of the Abatement Contractor. The Contractor is responsible for providing daily Cal/OSHA compliance monitoring as per 8 CCR 1529 for asbestos and CCR 1532.1 for lead.

- A. At minimum, the Contractor shall conduct representative breathing zone personal air monitoring of its employees, repeated daily or until a "negative exposure assessment", as derived in accordance with 29 CFR 1926.1101 (f)(2)(iii) and 8 CCR 1529 for asbestos.
- B. Employers must assess the amounts of lead breathed by workers on a regular basis for each trigger task as per 8 CCR 1532.1. This is usually done by employee breathing zone air sampling. Air sampling results are used to determine the protective measures needed as well as the type of respirator that must be worn for protection.

1. **Level 1 trigger tasks:** Spray painting, manual demolition, manual scraping or sanding, use of heat gun, power tool cleaning with dust collection system. Minimum required respirator: half-mask respirator with N-100, R-100 or P-100 filters.
  2. **Level 2 trigger tasks:** Using lead-containing mortar, lead burning, rivet busting, power tool cleaning without dust collection system, clean-up activities using dry expendable abrasives, abrasive blasting enclosure movement or removal. Minimum required respirator: air-supplied hood or helmet, or loose-fitting hood or helmet powered air purifying respirator with N-100, R-100 or P-100 filters.
  3. **Level 3 trigger tasks:** Abrasive blasting, welding, cutting, or torch burning on structures where lead-containing coatings or materials are present. Minimum required respirator: half-mask supplied air respirator operated in a positive pressure mode.
- C. Monitoring shall be conducted by a qualified air professional experienced and knowledgeable about the methods of air monitoring and in accordance with 29 CFR 1926.1101, 8 CCR 1529 and 8 CCR 1532.1.
- D. Monitoring results and appropriate laboratory analysis work shall be posted **within forty-eight (48) hours of the monitoring work.**

### **3.7 WORK PROCEDURES**

#### **3.7.1 MINOR DISTURBANCE OF ACM, ACCM, LBP AND LEAD CONTAINING PAINTS**

The intent of this section is to describe the minimum controls necessary during work which will impact identified or presumed asbestos containing materials/ asbestos containing construction material and lead based/containing paints

The scope of work will involve the disturbance and/or spot abatement/minor disturbances related to drilling through substrates which contain asbestos or lead including, but not limited to ceiling tile/mastic, plasters, stucco, gypsum board/joint compounds.

Engineering Controls/Setup:

1. Demarcate each work area with asbestos caution tape/signs, place polyethylene drop sheet beneath the area to be drilled and install temporary negative air pressure machine in the general vicinity of the activity. The negative air machine is to be exhausted to the outside of the room/building. If necessary and applicable, furniture/objects will need to be removed from the immediate area where disturbance is to occur or be covered with polyethylene sheeting.

Min. Resp. Protection:

1. Half face APR with P100 filters; provide personal monitoring and comply with Cal/OSHA requirements during removal. Provide personal monitoring and otherwise comply with Cal/OSHA requirements during removal.

Removal:

1. Drill through substrate at each individual hole where conduit or pipe will be run through a roof, ceiling, or wall with a HEPA vacuum attachment to a variable speed drill or hold a HEPA vacuum nozzle adjacent to the drill bit to collect any dust that is generated. The local HEPA exhaust system should exhaust continuously. Wet wipe the polyethylene sheeting when work is completed in each location and prior to a visual inspection of the area.

2. **Larger areas of removal (greater than small holes to accommodate conduit or pipe will be completed through the installation of a mini-containment or the use of a glove-bag. This work shall be completed in accordance with SCAQMD Procedure 1 or 2 respectively.**
3. Work to be performed by a licensed asbestos Abatement Contractor.

Preparation/Transport:

1. If any debris is generated, it should be HEPA vacuumed immediately and poly sheeting should be wet-wiped with rags/wipes and bagged immediately, using double six-mil marked bags. Keep wet and cover during transport to a dumpster.

Disposal:

1. Dispose of all friable materials as hazardous asbestos containing waste. A Hazardous Waste Shipment Record is required.

Air Monitoring:

1. Continuous, in-progress air sampling to be analyzed by PCM (NIOSH Method 7400) on-site at the end of each shift. If PCM samples fail, perform TEM analysis on a rush basis.

Clearance:

1. Minimum-Visual clearance per area. Depending on extent of disturbance, PCM clearances may be collected at the discretion of the consultant.

Training and Licensing

The drilling through the substrate and disturbance of asbestos containing materials and asbestos containing construction materials is to be completed by a licensed asbestos Abatement Contractor utilizing properly trained personnel in accordance with AHERA, Cal/OSHA, and the SCAQMD Rule 1403. Additionally, work impacting lead based or lead containing paints shall be completed in accordance with Cal/OSHA 1532.1 and, as applicable, the California Department of Public Health.

### **3.7.2 ASBESTOS-CONTAINING MATERIALS REMOVAL-TSI**

Engineering Controls:

**Set up is dependent on scope of work. Smaller scopes may be completed with lower level of engineering controls and shall be approved by District representative.**

1. Install a full containment work area isolation including critical barriers, a 3-stage worker decontamination facility and temporary negative pressure differential.
2. For elbow T.S.I., removal may also be performed using a glove bag technique. For glove bag removal, install critical barriers, drop floors, signs, and a two-stage worker decontamination facility.
3. For the door removal, if they can be undone at the hinges intact, a drop floor will suffice. Waste must be wrapped, labeled, and disposed of as hazardous waste.

Min. Resp. Protection:

1. Powered Air Purifying Respirators (PARP). The respiratory protection may be downgraded to a half-face APR if the Abatement Contractor can confirm based on objective data (personal air sampling)

that exposure levels to asbestos during removal of the identified material will be sufficient for that respirator.

2. Perform the required Cal/OSHA worker exposure air monitoring.

Removal:

1. Remove the material using manual means and wet methods. Allow surfactant to soak into material and remove in manageable sections. Do not let debris to accumulate, perform cleaning of up of loose debris continuously.

Preparation/Transport:

1. Package and label the waste immediately. Store all waste in a lockable storage dumpster.

Disposal:

1. Dispose of as friable, hazardous asbestos-containing waste. A waste shipment (manifest) will be required.
2. *Waste material reported with traces of asbestos (<1%) may be disposed of as non-hazardous waste if it can be easily separated.*

### **3.7.3 LEAD-BASED PAINT REMOVAL - PAINT STABILIZATION / COMPONENT REMOVAL**

Engineering Controls:

1. Install demarcation signage; drop floors, and critical barriers as necessary and a 2-stage worker decontamination facility with a wash station.

Min. Personal Protection:

1. Half-face air-purifying respirators equipped with HEPA-P100 filters. Disposable clothing (Tyvek [or equivalent] suits) and hand, foot, and eye protection is required.
2. Perform the required Cal/OSHA worker exposure air monitoring.

Removal:

1. Remove and stabilize all damaged, loose, and flaky paint prior to the component removal or surface preparation for repainting etc. Apply a paint sealer to the stabilized painted areas.
2. No mechanical removal such as saw cutting, torching, cutting, welding, etc. through lead-based paint shall be conducted. Painted components which may require cutting shall first be spot abated. The paint in the area to be cut shall first be removed entirely at a minimum six inches to each direction of the cut point. The Contractor will be required to submit a work plan, separate from this plan, for any planned work involving mechanical means or removal stated above. The plan must be reviewed and approved by the District prior to the Contractor beginning any work.

Preparation/Transport:

1. Package the waste generated by the paint stabilization and separate the waste into waste streams. Conduct the required waste characterization for disposal. (Refer to Section 3.3 of this document).

Disposal:

1. Dispose of all lead waste in accordance with federal, state, and local regulations.

### **3.7.5 LEAD-CONTAINING PAINT CONSTRUCTION RELATED WORK**

All construction work activities impacting lead-containing paints (LCP) (paints reported below 5,000 ppm) completed for this project, such as but not limited to demolition, removal, renovation etc. remain subject to Cal/OSHA worker exposure requirements (8 CCR 1532.1) including the use of respirators, protective clothing, training, air monitoring, waste disposal, etc. Further, it is the Contractor's responsibility to ensure that his workers are adequately protected to potential lead exposure during the initial monitoring period. It is the responsibility of the Abatement Contractor to fully comply with the requirements of the Cal/OSHA regulation. Cal/OSHA requirements are summarized below:

- a. Employers must assess the concentration of lead breathed by workers on a regular basis for each trigger task as per Section 1532.1(d). This is usually done by employee breathing zone air sampling. Air sampling results are used to determine the protective measures needed as well as the type of respirator that must be worn for protection.
  - i. **Level 1 trigger tasks:** Spray painting, manual demolition, manual scraping or sanding, use of heat gun, power tool cleaning with dust collection system. Minimum required respirator: half-mask respirator with N-100, R-100 or P-100 filters.
  - ii. **Level 2 trigger tasks:** Using lead-containing mortar, lead burning, rivet busting, power tool cleaning without dust collection system, clean-up activities using dry expendable abrasives, abrasive blasting, enclosure movement or removal. Minimum required respirator: air-supplied hood or helmet, or loose fitting hood or helmet powered air purifying respirator with N-100, R-100 or P-100 filters.
  - iii. **Level 3 trigger tasks** Abrasive blasting, welding, cutting, or torch burning on structures where lead-containing coatings or materials are present. Minimum required respirator: half-mask supplied air respirator operated in a positive pressure mode.

All lead waste shall be segregated into separate waste streams. The Contractor will be required to collect a sufficient number of samples to adequately characterize the waste stream. Sample analysis will include at a minimum, Total Threshold Limit Concentration (TTLC), Soluble Threshold Limit Concentration (STLC) and Toxicity Characteristic Leaching Procedure (TCLP). Refer to Section 3.3 for additional information.

## **End of Section**