

January 28, 2019

TO Carey Upton  
Chief Operations Officer  
Santa Monica - Malibu Unified School District

[cupton@smmusd.org](mailto:cupton@smmusd.org)

FROM Mark Smith  
Forensic Analytical Consulting Services  
2959 E Pacific Commerce Dr.  
Rancho Dominguez, CA 90221

[msmith@forensicanalytical.com](mailto:msmith@forensicanalytical.com)

JOB Malibu High School  
SITE 30215 Morning View Drive  
Malibu, California 90265

RE **Ambient Air Testing for Asbestos and Surface Dust Sampling for Lead**  
**FACS Project No. PJ39976**

---

This letter report presents the results of the limited asbestos air sampling and lead dust wipe sampling conducted by Forensic Analytical Consulting Services (FACS). At your request, FACS conducted air monitoring (to determine airborne asbestos fiber levels) and surface dust sampling (to determine settled lead dust levels) at various interior areas of the Malibu High School campus, located at 30215 Morning View Drive in Malibu, California. The sampling was requested due to occupant concerns that smoke infiltration from recent fires may have resulted in asbestos fiber impact or lead dust deposition. No known asbestos containing building materials or lead-based painted component impacts have occurred at the site.

The air sampling was conducted by FACS personnel certified by the California Division of Industrial Relations, Department of Occupational Safety and Health (Cal/OSHA) as a Certified Asbestos Consultant (CAC) or Certified Site Surveillance Technician (CSST). Dust wipe sampling was conducted by FACS personnel certified by California Department of Public Health (CDPH) as a Lead Inspector/Assessor, Project Monitor and/or Sampling Technician.

The samples were submitted to Amerisci Group's Carson, California laboratory. Air samples were submitted for transmission electron microscopy (TEM) analysis using AHERA protocol. These results are reported in asbestos structures per filter and asbestos structures per cubic centimeter of air. The dust wipe samples were analyzed by Atomic Absorption Spectroscopy (AAS), utilizing EPA Method 3050B/7000B. These results are reported in micrograms of lead per square foot.

Amerisci Group is an accredited laboratory that participates in the National Voluntary Laboratory Accreditation Program (NVLAP) quality assurance/quality control program for asbestos analysis (NVLAP No. 200346-0) and Environmental Laboratory Accreditation Program (ELAP Accreditation No. 2322).

As a reference point to the numbers generated by the analysis, the EPA requires a maximum average of 70 structures (or less) per square millimeter of sample filter area as the clearance criteria for reoccupation of an asbestos abatement area in schools, which equates to approximately 0.02 fibers per cubic centimeter of air (f/cc), with typical sampling parameters. An alternate EPA limit, for smaller work areas, is 0.01 f/cc. All air sample results were well below these limits. In fact, no asbestos structures were identified in any of the samples (detection limits were well below the EPA standards). Wipe sample results for lead dust were all below the California Department of Public Health (CDPH) regulatory limits for the surfaces tested (40 micrograms of lead per square foot for interior floors and 250 micrograms of lead per square foot for interior horizontal surfaces).

Laboratory reports, sampling data/chain-of-custody forms and completed copy of CDPH Form 8552 (required by CDPH), are contained in the Attachments.

Respectfully,  
FORENSIC ANALYTICAL

A handwritten signature in black ink, appearing to read 'M. Smith', with a horizontal line underneath.

Mark Smith

CAC No.00-2736

CDPH No. 7160

Attachments


Table I

Summary of Transmission Electron Microscopy (TEM) Results for Asbestos (air)

PJ39976; Malibu H.S.; Air And Surface Sampling

AmeriSci Sample #	Client Sample #	Dilution Factor	Air Filtered (liters)	Area Analyzed (sq. mm.)	* Analytical Sensitivity (struc/cc air)	Asbestos Structures Detected (Microns)		Structure Density (struc/sq mm)		Structure Concentration (struc/cc air)		Type of Asbestos
						0.5-5.0	>=5.0	Total	>=5.0	Total	>=5.0	
01 inside	TE326078		1464.7	.050	0.0052	0.0	0.0	<19.9	<19.9	<0.0052	<0.0052	NSD
Location: Building - Mako, Room 203, NW												
02 inside	TE326038		1455	.050	0.0053	0.0	0.0	<19.9	<19.9	<0.0053	<0.0053	NSD
Location: Building - Mako, Room 205 @ Entry												
03 inside	TE326080		1455	.050	0.0053	0.0	0.0	<19.9	<19.9	<0.0053	<0.0053	NSD
Location: Building - Mako, Room 207 @ Entry												
04 inside	TE326079		1455	.050	0.0053	0.0	0.0	<19.9	<19.9	<0.0053	<0.0053	NSD
Location: Building - Mako, Room 209 @ Entry												
05 inside	TE326082		1374.45	.060	0.0047	0.0	0.0	<16.6	<16.6	<0.0047	<0.0047	NSD
Location: Building - Mako, Room 211 @ Entry												
06 inside	TE326060		1435.6	.060	0.0045	0.0	0.0	<16.6	<16.6	<0.0045	<0.0045	NSD
Location: Building - Mako, Room 201 @ Entry												
07 inside	TE326068		1387.1	.060	0.0046	0.0	0.0	<16.6	<16.6	<0.0046	<0.0046	NSD
Location: Building - Mako, Room 200 @ Entry												
08 inside	TE326077		1377.4	.060	0.0046	0.0	0.0	<16.6	<16.6	<0.0046	<0.0046	NSD
Location: Building - Mako, Room 202 @ Entry												
09 inside	TE326081		1387.1	.060	0.0046	0.0	0.0	<16.6	<16.6	<0.0046	<0.0046	NSD
Location: Building - Mako, Room 204 @ Entry												
10 inside	TE442945		1377.4	.060	0.0046	0.0	0.0	<16.6	<16.6	<0.0046	<0.0046	NSD
Location: Building - Mako, Room 206 @ Entry												
11 inside	TE442943		1367.7	.060	0.0047	0.0	0.0	<16.6	<16.6	<0.0047	<0.0047	NSD
Location: Building - Mako, Room 208 @ Entry												
12 inside	TE442937		1377.4	.060	0.0046	0.0	0.0	<16.6	<16.6	<0.0046	<0.0046	NSD
Location: Building - Mako, Room 210 @ Entry												
13 inside	TE442941		1367.7	.060	0.0047	0.0	0.0	<16.6	<16.6	<0.0047	<0.0047	NSD
Location: Building - Mako, Room 212 @ Entry												

\* concentration represented by the detection of 1 structure  
 \*\* not analyzed  
 NSD: No Asbestos Structures Detected

Reviewed By: 

; Analyzed By:  TM

Date: 12/5/2018

Tyler D Miller

Table I

Summary of Transmission Electron Microscopy (TEM) Results for Asbestos (air)

PJ39976; Malibu H.S.; Air And Surface Sampling

AmeriSci Sample #	Client Sample #	Dilution Factor	Air Filtered (liters)	Area Analyzed (sq. mm.)	* Analytical Sensitivity (struc/cc air)	Asbestos Structures Detected (Microns)		Structure Density (struc/sq mm)		Structure Concentration (struc/cc air)		Type of Asbestos
						0.5-5.0	>=5.0	Total	>=5.0	Total	>=5.0	
14 inside	TE442947		1377.4	.060	0.0046	0.0	0.0	<16.6	<16.6	<0.0046	<0.0046	NSD
Location:	Building - Mako, Room Lounge, West											
15 inside	TE442948		1367.7	.060	0.0047	0.0	0.0	<16.6	<16.6	<0.0047	<0.0047	NSD
Location:	Building - Mako, Work Room, East											
16 inside	TE442950		1358	.060	0.0047	0.0	0.0	<16.6	<16.6	<0.0047	<0.0047	NSD
Location:	Building - Mako, Room 101B, South											
17 inside	TE442952		1358	.060	0.0047	0.0	0.0	<16.6	<16.6	<0.0047	<0.0047	NSD
Location:	Building - Mako, Room 103, Entry											
18 inside	TE442951		1358	.060	0.0047	0.0	0.0	<16.6	<16.6	<0.0047	<0.0047	NSD
Location:	Building - Mako, Room 105 Center											
19 inside	TE442954		1358	.060	0.0047	0.0	0.0	<16.6	<16.6	<0.0047	<0.0047	NSD
Location:	Building - Mako, Room 106 South											
20 inside	TE442929		1377.4	.060	0.0046	0.0	0.0	<16.6	<16.6	<0.0046	<0.0046	NSD
Location:	Building - Mako, Room 102 SW											
21 inside	TE442940		1351.35	.060	0.0047	0.0	0.0	<16.6	<16.6	<0.0047	<0.0047	NSD
Location:	Bldg. Thresher, Room 303, North											
22 inside	TE442939		1361.6	.060	0.0047	0.0	0.0	<16.6	<16.6	<0.0047	<0.0047	NSD
Location:	Bldg. Thresher, Room 302, South											
23 inside	TE442942		1383.05	.060	0.0046	0.0	0.0	<16.6	<16.6	<0.0046	<0.0046	NSD
Location:	Bldg. Leopard, Room 401, North											
24 inside	TE443260		1380	.060	0.0046	0.0	0.0	<16.6	<16.6	<0.0046	<0.0046	NSD
Location:	Bldg. Leopard, Room 402, West											
25 inside	TE443262		1352.4	.060	0.0047	0.0	0.0	<16.6	<16.6	<0.0047	<0.0047	NSD
Location:	Bldg. Angel, Room 500, East											
26 inside	TE443270		1358	.060	0.0047	0.0	0.0	<16.6	<16.6	<0.0047	<0.0047	NSD
Location:	Bldg. Angel, Room 502, North											

\* concentration represented by the detection of 1 structure  
 \*\* not analyzed  
 NSD: No Asbestos Structures Detected

Reviewed By:  ; Analyzed By: TM ; Date: 12/5/2018  
 Tyler D Miller



**Table I**  
**Summary of Transmission Electron Microscopy (TEM) Results for Asbestos (air)**  
 PJ39976; Malibu H.S.; Air And Surface Sampling

AmeriSci Sample #	Client Sample #	Dilution Factor	Air Filtered (liters)	Area Analyzed (sq. mm.)	* Analytical Sensitivity (struc/cc air)	Asbestos Structures Detected (Microns)		Structure Density (struc/sq mm)		Structure Concentration (struc/cc air)		Type of Asbestos
						0.5-5.0	>=5.0	Total	>=5.0	Total	>=5.0	
27 inside	TE443264		1358	.060	0.0047	0.0	0.0	<16.6	<16.6	<0.0047	<0.0047	NSD
Location: Bldg. Angel, Room 501, South												
28 inside	TE442930		1380	.060	0.0046	0.0	0.0	<16.6	<16.6	<0.0046	<0.0046	NSD
Location: Bldg. Thresher, Room 301, East												
29 inside**	TE442862		1380									
Location: (Sample Not Submitted) Bldg. Hammerhead, Room 601 @ Entry												
30 inside**	TE446822		1435.6									
Location: (Sample Not Submitted) Bldg. Hammerhead, Room 604 @ Entry												
31 inside	TE326075		1474.4	.050	0.0052	0.0	0.0	<19.9	<19.9	<0.0052	<0.0052	NSD
Location: Bldg. Hammerhead, Room 605 @ Entry												
32 inside	TE326073		1389.2	.060	0.0046	0.0	0.0	<16.6	<16.6	<0.0046	<0.0046	NSD
Location: Bldg. Hammerhead, Room 603 @ Entry												
33 inside	TE326072		1474.4	.050	0.0052	0.0	0.0	<19.9	<19.9	<0.0052	<0.0052	NSD
Location: Bldg. Hammerhead, Room 606 @ Entry												
34 inside	TE442855		1534.5	.050	0.0050	0.0	0.0	<19.9	<19.9	<0.0050	<0.0050	NSD
Location: Bldg. Hammerhead, Room 626 @ Entry												
35 inside	TE326069		1474.2	.050	0.0052	0.0	0.0	<19.9	<19.9	<0.0052	<0.0052	NSD
Location: Bldg. Hammerhead, Room 623 @ Entry												
36 inside	TE326064		1684.8	.050	0.0046	0.0	0.0	<19.9	<19.9	<0.0046	<0.0046	NSD
Location: Bldg. Hammerhead, Room 625 @ Entry												
37 inside	TE326070		1554.3	.050	0.0049	0.0	0.0	<19.9	<19.9	<0.0049	<0.0049	NSD
Location: Bldg. Hammerhead, Room 622 @ Entry												
38 inside	TE326071		1493.1	.050	0.0051	0.0	0.0	<19.9	<19.9	<0.0051	<0.0051	NSD
Location: Bldg. Hammerhead, Room 624 @ Entry												
39 inside	TE326047		1323	.060	0.0048	0.0	0.0	<16.6	<16.6	<0.0048	<0.0048	NSD
Location: Bldg. Hammerhead, Room 621 @ Entry												

\* concentration represented by the detection of 1 structure  
 \*\* not analyzed

NSD: No Asbestos Structures Detected

Reviewed By: 

; Analyzed By: 

Date: 12/5/2018



Tyler D Miller

Client Name: Forensic Analytical Consulting Services

**Table I**  
**Summary of Transmission Electron Microscopy (TEM) Results for Asbestos (air)**  
 PJ39976; Malibu H.S.; Air And Surface Sampling

AmeriSci Sample #	Client Sample #	Dilution Factor	Air Filtered (liters)	Area Analyzed (sq. mm.)	* Analytical Sensitivity (struc/cc air)	Asbestos Structures Detected (Microns)		Structure Density (struc/sq mm)		Structure Concentration (struc/cc air)		Type of Asbestos
						0.5-5.0	>=5.0	>=5.0	Total	>=5.0	Total	
40 inside	TE326050		1453.6	.050	0.0053	0.0	0.0	<19.9	<19.9	<0.0053	<0.0053	NSD
Location: Bldg. Hammerhead, Room 602 @ Entry												
41 inside	TE443269		1540.35	.050	0.0050	0.0	0.0	<19.9	<19.9	<0.0050	<0.0050	NSD
Location: Portable 513, School Nurse												
42 inside	TE442865		1458.85	.050	0.0053	0.0	0.0	<19.9	<19.9	<0.0053	<0.0053	NSD
Location: Portable 512, Attendance												
43 inside	TE326051		1490.4	.050	0.0052	0.0	0.0	<19.9	<19.9	<0.0052	<0.0052	NSD
Location: Angel Building Rm. 505 Pt. 1/N												
44 inside	TE326059		1440.95	.050	0.0053	0.0	0.0	<19.9	<19.9	<0.0053	<0.0053	NSD
Location: Angel Building Rm. 505, South												
45 inside	TE442854		1552	.050	0.0049	0.0	0.0	<19.9	<19.9	<0.0049	<0.0049	NSD
Location: Angel Building Rm. 506, Center												
46 inside	TE442895		1542.3	.050	0.0050	0.0	0.0	<19.9	<19.9	<0.0050	<0.0050	NSD
Location: Portable 511 Rm. 511, Entry												
47 blank**	TE442863		0									
Location: Blank												
48 blank**	TE442897		0									
Location: Blank												
49 blank**	TE442857		0									
Location: Blank												

\* concentration represented by the detection of 1 structure  
 \*\* not analyzed  
 NSD: No Asbestos Structures Detected

Reviewed By:  ; Analyzed By:  ; Date: 12/5/2018  
 Tyler D Miller





# Asbestos / Lead Analysis Chain of Custody

**AMERISCI LOS ANGELES**  
 24416 S Main St. Suite 308  
 Carson, CA 90745  
 Phone (310) 834-4868  
 Fax (310) 834-4772

AMERISCI JOB #:  
**918121099**

<b>COMPANY:</b> Forensic Analytical Consulting Services		<b>ADDRESS:</b> 2959 Pacific Commerce Drive, Rancho Dominguez 90221					<b>P.O.#:</b>		
<b>PROJECT INFORMATION</b>		<b>ANALYSIS TYPE</b>	<b>TURNAROUND TIME</b>					<b>AIR FILTER INFORMATION:</b>	
<b>JOB NAME:</b> Malibu H.S.		TEM AHERA	RUSH	24 HR	48 HR	72 HR	5 DAY	OTHER	MCE
<b>JOB NUMBER:</b> PJ39976		PLM Bulk							PC
<b>JOB MANAGER:</b> Mark Smith		PCM Air							25 mm
<b>JOB DESCRIPTION:</b> Air and Surface Sampling		PLM 1000 P.C.							37 mm
		Lead Air							0.45 um
		Lead Wipe							0.80 um
		Lead Paint / Soil							TEMP:
		OTHER:							OTHER: 2050 #9523

**INITIAL RESULTS DELIVERY:**  FAX  EMAIL  VERBAL  MAIL ONLY

**REPORTS TO:** Mark Smith

**INVOICE TO:**

**COMMENTS:**

**RETURN SAMPLES** Yes

**PHONE:**

**FAX:**

**EMAIL:** msmith@forensicanalytical.com

**CELL:**

SAMPLE ID	SAMPLE LOCATION	START TIME	STOP TIME	TOTAL TIME X	LITERS /MIN.	TOTAL VOLUME	DATE COLLECTED
TE320078	Building - Malibu, Room 205, NW	0937	12:08	151	9.7	1464.7	12/4/18
6038	Room 205, Center	0940	12:10	150	9.7	1455	
6080	207	0942	12:12	150	9.7	1455	
6079	209	0944	12:14	150	9.7	1455	
6082	211	0946	11:45	149	4.9	374.4	
6060	201	0953	12:21	148	9.7	1435.6	
6064	202	0955	12:18	143		1387.1	
6077	203	0958	12:20	142		1377.4	
6081	204	1000	12:23	143		1387.1	
TE44 2945	206	1002	12:24	142		1377.4	
2943	208	1004	12:25	143		1387.1	
2937	210	1006	12:28	142		1377.4	
2941	212	1008	12:29	141		1367.7	
2947	Large, West	1016	12:38	142		1377.4	
2948	Workroom, east	1018	12:39	143		1387.1	
2950	101B, south	1020	12:40	140		1358	
2952	103, entry	1023	12:43	140		1358	
2951	105, center	1025	12:45	140		1358	
2934	106 south	1028	12:47	140		1358	
2939	102 SW	1041	12:48	140		1358	

<b>SAMPLED BY:</b> Charles Johnson	<b>DATE/TIME:</b> 12/4/18 various	<b>RECEIVED BY:</b> [Signature]	<b>DATE/TIME:</b> 12/4/18 10:20
<b>RELINQUISHED BY:</b> [Signature]	<b>DATE/TIME:</b> 12/4/18 14:19	<b>RECEIVED BY:</b>	<b>DATE/TIME:</b>
<b>RELINQUISHED BY:</b> [Signature]	<b>DATE/TIME:</b> 12/4/18 20:30	<b>RECEIVED IN LAB BY:</b> [Signature]	<b>DATE/TIME:</b> 12/5/18 00:50





# Asbestos / Lead Analysis Chain of Custody

**AMERISCI LOS ANGELES**  
 24416 S Main St. Suite 308  
 Carson, CA 90745  
 Phone (310) 834-4868  
 Fax (310) 834-4772

AMERISCI JOB #:  
918121039

<b>COMPANY:</b> Forensic Analytical Consulting Services		<b>ADDRESS:</b> 2959 Pacific Commerce Drive, Rancho Dominguez 90221					<b>P.O.#:</b>			
<b>PROJECT INFORMATION</b>		<b>ANALYSIS TYPE</b>		<b>TURNAROUND TIME</b>			<b>AIR FILTER INFORMATION:</b>			
<b>JOB NAME:</b> Malibu H.S.		TEM AHERA		RUSH	24 HR	48 HR	72 HR	5 DAY	OTHER	MCE
<b>JOB NUMBER:</b>		PLM Bulk		X						PC
<b>JOB MANAGER:</b> Mark Smith		PCM Air								25 mm
<b>JOB DESCRIPTION:</b> Air and Surface Sampling		PLM 1000 P.C.								37 mm
		Lead Air								0.45 um
		Lead Wipe								0.80 um
		Lead Paint / Soil								TEMP:
		OTHER:								OTHER: R010#99523

**INITIAL RESULTS DELIVERY:**  FAX  EMAIL  VERBAL  MAIL ONLY

**REPORTS TO:** Mark Smith

**INVOICE TO:**

**COMMENTS:** *House Room 624 9.45 Lpm (CS)  
House for Room 401 9.95 Lpm (CS)*

**RETURN SAMPLES:** Yes

**PHONE:**

**FAX:**

**EMAIL:** msmith@forensicanalytical.com

**CELL:**

SAMPLE ID	SAMPLE LOCATION	START TIME	STOP TIME	TOTAL TIME X	LITERS /MIN.	TOTAL VOLUME	DATE COLLECTED
TE44 2940	Bldg-Thresher, room 303, north	1045	1308	143	9.45	1351.35	12/4/18
2939	303, south	1049	1317	148	9.2	1361.6	
2942	leopard 401, north	1051	1310	139	9.2	1283.05	
3260	(S) Angel leopard 402, west	1055	1329	150	9.2	1380	
3262	leopard 502, east	1100	1327	147	9.2	1352.4	
3270	502 north	1102	1330	140	9.7	1358	
3264	501 south	1114	1324	140	9.7	1358	
2930	Thresher 301, east	1343	1613	150	9.2	1380	
2912	Hammerhead 601, south	1352	1622	150	9.2	1380	
TE44 6075	TE44 6822 Bldg 604	1401	1629	148	9.7	1435.4	
TE 32 6075	Bldg 605	1403	1635	152	9.7	1474.4	
TE 32 6073	603	1407	1638	151	9.2	1389.2	
TE 32 6072	604	1409	1641	152	9.7	1474.4	
TE44 2855	626	1414	1649	155	9.9	1534.5	
TE 32 6069	625	1416	1652	154	9.45	1474.2	
TE 32 6064	625	2149	1455	156	10.8	1484.8	
TE 32 6070	622	1421	1658	157	9.9	1554.3	
TE 32 6071	624	1422	1700	158	9.2	1493.1	
TE 32 6047	621	1426	1646	140	9.45	1323	
TE 32 6050	602	1355	1635	158	9.0	1422	

**SAMPLED BY:** *Chade Johnson* **DATE/TIME:** 12/4/18 **RECEIVED BY:** *[Signature]* **DATE/TIME:** 12/4/18 08:30

**RELINQUISHED BY:** *[Signature]* **DATE/TIME:** 12/4/18 18:19 **RECEIVED BY:** *[Signature]* **DATE/TIME:**

**RELINQUISHED BY:** *[Signature]* **DATE/TIME:** 12/4/18 20:30 **RECEIVED IN LAB BY:** *[Signature]* **DATE/TIME:** 12/5/18 00:00





Asbestos / Lead Analysis Chain of Custody

AMERISCI LOS ANGELES  
 24416 S Main St. Suite 308  
 Carson, CA 90745  
 Phone (310) 834-4868  
 Fax (310) 834-4772

AMERISCI JOB #:  
**918121079**

<b>COMPANY:</b> Forensic Analytical Consulting Services		<b>ADDRESS:</b> 2959 Pacific Commerce Drive, Rancho Dominguez 90221					<b>P.O.#:</b>		
<b>PROJECT INFORMATION</b>		<b>ANALYSIS TYPE</b>	<b>TURNAROUND TIME</b>					<b>AIR FILTER INFORMATION:</b>	
<b>JOB NAME:</b> Malibu H.S.		TEM AHERA	RUSH	24 HR	48 HR	72 HR	5 DAY	OTHER	MCE
<b>JOB NUMBER:</b> P539976		PLM Bulk	X						PC
<b>JOB MANAGER:</b> Mark Smith		PCM Air							25 mm
<b>JOB DESCRIPTION:</b> Air and Surface Sampling		PLM 1000 P.C.							37 mm
		Lead Air							0.45 um
		Lead Wipe							0.80 um
		Lead Paint / Soil							TEMP:
		OTHER:							OTHER: photo # 91523

INITIAL RESULTS DELIVERY:  FAX  EMAIL  VERBAL  MAIL ONLY

REPORTS TO: Mark Smith

INVOICE TO:

COMMENTS:

RETURN SAMPLES Yes

PHONE:

FAX:

EMAIL: msmith@forensicanalytical.com

CELL:

SAMPLE ID	SAMPLE LOCATION	START TIME	STOP TIME	TOTAL TIME X	LITERS /MIN.	TOTAL VOLUME	DATE COLLECTED
TE 44 3269	Portable 513 School Nurse	1436	1719	163	9.95	1458.95	12/4/18
TE 44 2805	" 512 attendance	1442	1725	163	8.95	1458.95	
<del>TE 44 2805</del>	<del>VAID (S) Attendant office 511</del>	<del>1442</del>	<del>1725</del>	<del>163</del>	<del>8.7</del>	<del>1458.95</del>	
TE 32 6051	Angel Building Rm 505 pt. 1/W	1448	1730	162	9.2	1490.4	
TE 32 6059	↓ ↓ Rm 505, South	1451	1732	161	8.95	1440.95	
TE 44 2854	↓ ↓ Rm 506, Pentel	1457	1737	160	9.7	1552	
TE 44 2895	Portable 511 Rm 511, entry	1502	1741	159	9.7	1542.30	↓
TE 44 2803	Blank						
TE 44 2897	↓						
TE 44 2857	↓						

SAMPLED BY: <i>Charles Johnson</i>	DATE/TIME: 12/4/18 various	RECEIVED BY: <i>[Signature]</i>	DATE/TIME: 12/4/18 18:20
RELINQUISHED BY: <i>[Signature]</i>	DATE/TIME: 12/4/18 18:01	RECEIVED BY:	DATE/TIME:
RELINQUISHED BY: <i>[Signature]</i>	DATE/TIME: 12/5/18 20:20	RECEIVED IN LAB BY: <i>[Signature]</i>	DATE/TIME: 12/5/18 08:00

918121079

**Subject:** Re: <Missing and Total Volume Don't Match> Fwd: Samples Don't Match, Job# PJ39976 - 918121079  
**From:** Charlé Johnson <cjohnson@forensicanalytical.com>  
**Date:** 12/5/2018 12:11 PM  
**To:** Mark Smith <msmith@forensicanalytical.com>  
**CC:** Deeta Hong <dhong@forensicanalytical.com>, Mee Jones <pjones@amerisci.com>, ameriscila@amerisci.com

Good Afternoon!! Please see notes below regarding your questions:

- #TE442943 (1367.7L), (your calculations are correct)
- #TE442929 (1377.4L), (your calculations are correct)
- #TE442942 Missing Flow Rate (flow rate is 9.95 lpm)**
- #TE326071 Missing Flow Rate (flow rate is 9.45 lpm)**
- #TE326050 (1453.6L) (your calculations are correct)

Thanks  
Charle'

Sent from my iPhone

On Dec 5, 2018, at 11:28 AM, Mark Smith <msmith@forensicanalytical.com> wrote:

Deeta and Charle',

Please address immediately. Thank you.

**Mark Smith**

Senior Project Manager  
Forensic Analytical Consulting Services, Inc.  
2959 Pacific Commerce Drive  
Rancho Dominguez, CA 90221  
P: 310-668-5629 | F: 310-763-8684  
msmith@forensicanalytical.com | <http://www.forensicanalytical.com>

**Follow us on Social Media!**

----- Forwarded message -----

**From:** Mee Jones <pjones@amerisci.com>  
**Date:** Wed, Dec 5, 2018 at 11:24 AM  
**Subject:** <Missing and Total Volume Don't Match> Fwd: Samples Don't Match, Job# PJ39976 - 918121079  
**To:** Mark Smith <msmith@forensicanalytical.com>, AmeriSci LA <ameriscila@amerisci.com>

Hello

For the attached COC on The calculations Total Volume Don't Match.  
#TE442943 (1367.7L),

Rec'd by: Jones 12/5/18 12:40

918121079

**Subject:** Re: Samples Don't Match, Job# PJ39976 - 918121079  
**From:** Charlé Johnson <cjohnson@forensicanalytical.com>  
**Date:** 12/5/2018 12:12 PM  
**To:** Mee Jones <pjones@amerisci.com>  
**CC:** Mark Smith <msmith@forensicanalytical.com>, ameriscila@amerisci.com, Deeta Hong <dhong@forensicanalytical.com>

Yes Please! I will retest those areas on Friday.

Thanks

Sent from my iPhone

On Dec 5, 2018, at 12:10 PM, Mee Jones <pjones@amerisci.com> wrote:

So, Do you want to void two extra samples and two samples on the COC TE442862 and TE446822?

Please confirm.

Thank you

On 12/5/2018 11:27 AM, Mark Smith wrote:

Mee,

Please void those samples. Our team will retest and resubmit. Thank you.

Regards,

**Mark Smith**

Senior Project Manager  
Forensic Analytical Consulting Services, Inc.  
2959 Pacific Commerce Drive  
Rancho Dominguez, CA 90221  
P: 310-668-5629 | F: 310-763-8684  
msmith@forensicanalytical.com | <http://www.forensicanalytical.com>

**Follow us on Social Media!**

On Wed, Dec 5, 2018 at 8:34 AM Mee Jones <pjones@amerisci.com> wrote:

Good Morning,

For the attached COC we are missing Sample ID # TE44 6822 - Bldg. 604.

We have two extra samples labeled as #TE442946 - 211 and #TE32 6053 - 601.

Rec'd by: p Jones 12/5/18 @ 12:30



9181279

And on the coc Sample ID# TE 44 2862 - 601 But on the air cassettes labeled as -  
"604"

Please let us know what you would like us to do.

Thank you

--

Mee Jones  
AmeriSci Los Angeles  
24416 S. Main St. Suite 308  
Carson, CA 90745  
Office (310) 834-4868  
Fax (310) 834-4772  
[www.amerisci.com](http://www.amerisci.com)

--

Mee Jones  
AmeriSci Los Angeles  
24416 S. Main St. Suite 308  
Carson, CA 90745  
Office (310) 834-4868  
Fax (310) 834-4772  
[www.amerisci.com](http://www.amerisci.com)

Feed Dry, prones 12/5/18 @ 12.30



AmeriSci Job #: 918121174

Client Name: Forensic Analytical Consulting Services

Table I

Summary of Transmission Electron Microscopy (TEM) Results for Asbestos (air)

PJ39976; Malibu H.S.; Air And Surface Sampling

AmeriSci Sample #	Client Sample #	Dilution Factor	Air Filtered (liters)	Area Analyzed (sq. mm.)	* Analytical Sensitivity (struc/cc air)	Asbestos Structures Detected (Microns)		Structure Density (struc/sq mm)		Structure Concentration (struc/cc air)		Type of Asbestos
						0.5-5.0	>=5.0	Total	>=5.0	Total	>=5.0	
01 inside	104		1382.4	.060	0.0046	0.0	0.0	<16.6	<16.6	<0.0046	<0.0046	NSD
Location:	Room 104 (200 Bldg)											
02 inside	211		1372.8	.060	0.0047	0.0	0.0	<16.6	<16.6	<0.0047	<0.0047	NSD
Location:	Room 211 (200 Bldg)											
03 inside	601		1372.4	.060	0.0047	0.0	0.0	<16.6	<16.6	<0.0047	<0.0047	NSD
Location:	Room 601 (600 Bldg)											
04 inside	604		1401.6	.060	0.0046	0.0	0.0	<16.6	<16.6	<0.0046	<0.0046	NSD
Location:	Room 604 (600 Bldg)											
05 inside	01		1392	.060	0.0046	0.0	0.0	<16.6	<16.6	<0.0046	<0.0046	NSD
Location:	Kitchen N. End Ctr.											
06 inside	02		1372.8	.060	0.0047	0.0	0.0	<16.6	<16.6	<0.0047	<0.0047	NSD
Location:	Serving Room S.E. Area											
07 inside	03		1353.6	.060	0.0047	0.0	0.0	<16.6	<16.6	<0.0047	<0.0047	NSD
Location:	Dressing Room S.E. Area											
08 inside	04		1353.6	.060	0.0047	0.0	0.0	<16.6	<16.6	<0.0047	<0.0047	NSD
Location:	Stage S. End											
09 inside	05		1353.6	.060	0.0047	0.0	0.0	<16.6	<16.6	<0.0047	<0.0047	NSD
Location:	Auditorium N. Center											
10 inside	06		1353.6	.060	0.0047	0.0	0.0	<16.6	<16.6	<0.0047	<0.0047	NSD
Location:	Auditorium S.E. Area											
11 inside	07		1353.6	.060	0.0047	0.0	0.0	<16.6	<16.6	<0.0047	<0.0047	NSD
Location:	Hatch Line Service Counter											
12 inside	P5		1363.2	.060	0.0047	0.0	0.0	<16.6	<16.6	<0.0047	<0.0047	NSD
Location:	Room P5 S.E. Area											
13 inside	P6		1372.8	.060	0.0047	0.0	0.0	<16.6	<16.6	<0.0047	<0.0047	NSD
Location:	Room P6 S. Center											

\* concentration represented by the detection of 1 structure  
 \*\* not analyzed  
 NSD: No Asbestos Structures Detected

Reviewed By:  ; Analyzed By:  Date: 12/8/2018

Glenn F. Massey



Table I

Summary of Transmission Electron Microscopy (TEM) Results for Asbestos (air)

PJ39976; Malibu H.S.; Air And Surface Sampling

AmeriSci Sample #	Client Sample #	Dilution Factor	Air Filtered (liters)	Area Analyzed (sq. mm.)	* Analytical Sensitivity (struc/cc air)	Asbestos Structures Detected (Microns)		Structure Density (struc/sq mm)		Structure Concentration (struc/cc air)		Type of Asbestos
						0.5-5.0	>=5.0	Total	>=5.0	Total	>=5.0	
14 inside	P7		1372.8	.060	0.0047	0.0	0.0	<16.6	<16.6	<0.0047	<0.0047	NSD
Location: Room P7 S.W. Area												
15 inside	P8		1382.4	.060	0.0046	0.0	0.0	<16.6	<16.6	<0.0046	<0.0046	NSD
Location: Room P8 S.E. Area												
16 inside	P9		1382.4	.060	0.0046	0.0	0.0	<16.6	<16.6	<0.0046	<0.0046	NSD
Location: Room P9 S.W. Area												
17 inside	P2		1382.4	.060	0.0046	0.0	0.0	<16.6	<16.6	<0.0046	<0.0046	NSD
Location: Rm P2 S. Center												
18 inside	P3		1392	.060	0.0046	0.0	0.0	<16.6	<16.6	<0.0046	<0.0046	NSD
Location: Rm P3 N.W. Area												
19 inside	P4		1392	.060	0.0046	0.0	0.0	<16.6	<16.6	<0.0046	<0.0046	NSD
Location: Rm P4 N.E. Area												
20 inside	LI		1392	.060	0.0046	0.0	0.0	<16.6	<16.6	<0.0046	<0.0046	NSD
Location: Library E. Central Area												
21 inside	08		1470	.060	0.0044	0.0	0.0	<16.6	<16.6	<0.0044	<0.0044	NSD
Location: Gym (New), South												
22 inside	09		1386	.060	0.0046	0.0	0.0	<16.6	<16.6	<0.0046	<0.0046	NSD
Location: Gym (New), West												
23 inside	10		1386	.060	0.0046	0.0	0.0	<16.6	<16.6	<0.0046	<0.0046	NSD
Location: Gym (New), North												
24 inside	11		1386	.060	0.0046	0.0	0.0	<16.6	<16.6	<0.0046	<0.0046	NSD
Location: Girls Varsity Teamroom, East												
25 inside	12		1410	.060	0.0045	0.0	0.0	<16.6	<16.6	<0.0045	<0.0045	NSD
Location: Athletic Directors Office, East												
26 inside	13		1363	.060	0.0047	0.0	0.0	<16.6	<16.6	<0.0047	<0.0047	NSD
Location: Girl's New Locker Room, West												

\* concentration represented by the detection of 1 structure  
 \*\* not analyzed  
 NSD: No Asbestos Structures Detected

Reviewed By:  ; Analyzed By:  ; Date: 12/8/2018  
 Glenn F. Massey

Client Name: Forensic Analytical Consulting Services



Table I

Summary of Transmission Electron Microscopy (TEM) Results for Asbestos (air)

PJ39976; Malibu H.S.; Air And Surface Sampling

AmeriSci Sample #	Client Sample #	Dilution Factor	Air Filtered (liters)	Area Analyzed (sq. mm.)	* Analytical Sensitivity (struc/cc air)	Asbestos Structures Detected (Microns)		Structure Density (struc/sq mm)		Structure Concentration (struc/cc air)		Type of Asbestos
						0.5-5.0	>=5.0	Total	>=5.0	Total	>=5.0	
27 inside	14		1363	.060	0.0047	0.0	0.0	<16.6	<16.6	<0.0047	<0.0047	NSD
Location: Boy's New Locker Room, West												
28 inside	15		1363	.060	0.0047	0.0	0.0	<16.6	<16.6	<0.0047	<0.0047	NSD
Location: Old Gym, West												
29 inside	16		1363	.060	0.0047	0.0	0.0	<16.6	<16.6	<0.0047	<0.0047	NSD
Location: Old Gym, North												
30 inside	17		1363	.060	0.0047	0.0	0.0	<16.6	<16.6	<0.0047	<0.0047	NSD
Location: Old Gym, East												
31 inside	18		1363	.060	0.0047	0.0	0.0	<16.6	<16.6	<0.0047	<0.0047	NSD
Location: Weight Room, Center												
32 inside	19		1363	.060	0.0047	0.0	0.0	<16.6	<16.6	<0.0047	<0.0047	NSD
Location: Old Boys Locker Room, South												
33 inside	20		1363	.060	0.0047	0.0	0.0	<16.6	<16.6	<0.0047	<0.0047	NSD
Location: Old Boys Locker Room, East												
34 inside	21		1379.5	.060	0.0046	0.0	0.0	<16.6	<16.6	<0.0046	<0.0046	NSD
Location: Boy's P.E. Office (Old), Ctr.												
35 inside	22		1379.5	.060	0.0046	0.0	0.0	<16.6	<16.6	<0.0046	<0.0046	NSD
Location: Independent Study Program, Ctr.												
36 inside	23		1534.5	.060	0.0042	0.0	0.0	<16.6	<16.6	<0.0042	<0.0042	NSD
Location: Office 705 Girls W. Ctr.												
37 inside	24		1379.5	.060	0.0046	0.0	0.0	<16.6	<16.6	<0.0046	<0.0046	NSD
Location: Girl's Locker Room West												
38 inside	25		1379.5	.060	0.0046	0.0	0.0	<16.6	<16.6	<0.0046	<0.0046	NSD
Location: Girl's Locker Room North												
39 inside	26		1534.5	.060	0.0042	0.0	0.0	<16.6	<16.6	<0.0042	<0.0042	NSD
Location: Athletic Training Room (708), Ctr.												

\* concentration represented by the detection of 1 structure  
 \*\* not analyzed  
 NSD: No Asbestos Structures Detected

Reviewed By:  ; Analyzed By:  ; Date: 12/8/2018  
 Glenn F. Massey

Client Name: Forensic Analytical Consulting Services

**Table I**  
**Summary of Transmission Electron Microscopy (TEM) Results for Asbestos (air)**  
 PJ39976; Malibu H.S.; Air And Surface Sampling

AmeriSci Sample #	Client Sample #	Dilution Factor	Air Filtered (liters)	Area Analyzed (sq. mm.)	* Analytical Sensitivity (struc/cc air)	Asbestos Structures Detected (Microns)		Structure Density (struc/sq mm)		Structure Concentration (struc/cc air)		Type of Asbestos
						0.5-5.0	>=5.0	>=5.0	Total	>=5.0	Total	
40 inside	27		1430.4	.060	0.0045	0.0	0.0	<16.6	<16.6	<0.0045	<0.0045	NSD
<b>Location:</b> Club House Computer Rm. N.E.												
41 inside	28		1411.2	.060	0.0045	0.0	0.0	<16.6	<16.6	<0.0045	<0.0045	NSD
<b>Location:</b> Club House Computer Rm. Office Door												
42 inside	29		1411.2	.060	0.0045	0.0	0.0	<16.6	<16.6	<0.0045	<0.0045	NSD
<b>Location:</b> Club House Reception N.W.												
43 inside	30		1401.6	.060	0.0046	0.0	0.0	<16.6	<16.6	<0.0046	<0.0046	NSD
<b>Location:</b> Club House Kitchen E. Ctr.												
44 inside	31		1411.2	.060	0.0045	0.0	0.0	<16.6	<16.6	<0.0045	<0.0045	NSD
<b>Location:</b> Club House Games Room N.E.												
45 inside	32		1401.6	.060	0.0046	0.0	0.0	<16.6	<16.6	<0.0046	<0.0046	NSD
<b>Location:</b> Club House Chill Room S.E.												
46 inside	33		1392	.060	0.0046	0.0	0.0	<16.6	<16.6	<0.0046	<0.0046	NSD
<b>Location:</b> Club House N.E. Office Ctr.												
47 inside	34		1353.6	.060	0.0047	0.0	0.0	<16.6	<16.6	<0.0047	<0.0047	NSD
<b>Location:</b> Club House S.E. Office Ctr.												
48 inside	35		1392	.060	0.0046	0.0	0.0	<16.6	<16.6	<0.0046	<0.0046	NSD
<b>Location:</b> Brent's Club S.E. Office Ctr.												
49 inside	36		1401.6	.060	0.0046	0.0	0.0	<16.6	<16.6	<0.0046	<0.0046	NSD
<b>Location:</b> Brent's Club Ctr. Office Ctr.												
50 inside	37		1392	.060	0.0046	0.0	0.0	<16.6	<16.6	<0.0046	<0.0046	NSD
<b>Location:</b> Brent's Club S.E. Office Ctr.												
51 blank**	B1		0									
<b>Location:</b> Blank												
52 blank**	B2		0									
<b>Location:</b> Blank												

\* concentration represented by the detection of 1 structure  
 \*\* not analyzed

NSD: No Asbestos Structures Detected

Reviewed By:  ; Analyzed By:  Date: 12/8/2018

Glenn F. Massey

Client Name: Forensic Analytical Consulting Services

Table I

Summary of Transmission Electron Microscopy (TEM) Results for Asbestos (air)

PJ39976; Malibu H.S.; Air And Surface Sampling


AmeriSci Sample #	Client Sample #	Dilution Factor	Air Filtered (liters)	Area Analyzed (sq. mm.)	* Analytical Sensitivity (struc/cc air)	Asbestos Structures Detected (Microns)		Structure Density (struc/sq mm)		Structure Concentration (struc/cc air)		Type of Asbestos
						0.5-5.0	>=5.0	Total	>=5.0	Total	>=5.0	
53 blank**	B3		0									

Location: Blank

\* concentration represented by the detection of 1 structure

\*\* not analyzed

NSD: No Asbestos Structures Detected

Reviewed By:  ; Analyzed By:  Date: 12/8/2018

NVLAP#: 200346-0

Glenn F. Massey





Asbestos / Lead Analysis Chain of Custody

AMERISCI LOS ANGELES  
 24416 S Main St. Suite 308  
 Carson, CA 90745  
 Phone (310) 834-4868  
 Fax (310) 834-4772

AMERISCI JOB #:  
918121174

COMPANY: Forensic Analytical Consulting Services	ADDRESS: 2959 Pacific Commerce Drive, Rancho Dominguez 90221	P.O.#:						
PROJECT INFORMATION	ANALYSIS TYPE	TURNAROUND TIME						AIR FILTER INFORMATION:
		RUSH	24 HR	48 HR	72 HR	5 DAY	OTHER	
JOB NAME: Malibu H.S.	TEM AHERA	X						MCE
JOB NUMBER: <span style="font-size: 1.5em;">P539976</span>	PLM Bulk							PC
JOB MANAGER: Mark Smith	PCM Air							25 mm X
JOB DESCRIPTION: Air and Surface Sampling	PLM 1000 P.C.							37 mm
	Lead Air							0.45 um
	Lead Wipe							0.80 um
	Lead Paint / Soil							TEMP:
	OTHER:							OTHER: <span style="font-size: 1.2em;">Photo 105416</span>

INITIAL RESULTS DELIVERY:  FAX  EMAIL  VERBAL  MAIL ONLY

REPORTS TO: Mark Smith

INVOICE TO:

COMMENTS:

RETURN SAMPLES YES  NO

PHONE:

FAX:

EMAIL: msmith@forensicanalytical.com

CELL:

SAMPLE ID	SAMPLE LOCATION	START TIME	STOP TIME	TOTAL TIME X	LITERS /MIN.	TOTAL VOLUME	DATE COLLECTED
104	Room 104 (200 Bldg)	0833	1057	144	9.6	1382.4	12/7/18
211	211 " "	0838	1101	143	9.6	1372.8	12/7/18
601	601 600 Bldg	0843	1109	146	9.4	1401.6	12/7/18
604	604 " "	0845	1111	146	9.6	1401.6	12/7/18
01	Kitchen N. end ctr.	0853	1118	145	9.6	1392	
02	Serving room SE area	0857	1120	143	9.6	1372.8	
03	Dressing room SE area	0902	1123	141	9.6	1353.6	
04	Stage S. end	0905	1126	141	9.6	1353.6	
05	Auditorium N. center	0907	1128	141	9.6	1353.6	
06	Auditorium SE area	0909	1130	141	9.6	1353.6	
07	Hatch line service counter	0914	1134	141	9.6	1353.6	
P5	Room P5 SE area	0959	1221	142	9.6	1363.2	
P6	Room P6 S. center	1001	1224	143	9.6	1372.8	
P7	Room P7 SW area	1004	1227	143	9.6	1372.8	
P8	Room P8 SE area	1007	1231	144	9.6	1382.4	
P9	Room P9 SW area	1010	1234	144	9.6	1382.4	
P2	Rm P2 S. center	1012	1236	144	9.6	1382.4	
P3	Rm P3 NW area	1014	1239	145	9.6	1392.0	
P4	Rm. P4 NE area	1016	1241	145	9.6	1392.0	
LI	Library E. central area	1018	1246	148	9.4	1391.2	

SAMPLED BY:	DATE/TIME:	RECEIVED BY:	DATE/TIME:
RELINQUISHED BY:	DATE/TIME:	RECEIVED BY:	DATE/TIME:
RELINQUISHED BY:	DATE/TIME:	RECEIVED IN LAB BY:	DATE/TIME:

12/07/18 19:30m

12/8/18 8:00









Asbestos / Lead Analysis Chain of Custody

AMERISCI LOS ANGELES  
 24416 S Main St. Suite 308  
 Carson, CA 90745  
 Phone (310) 834-4868  
 Fax (310) 834-4772

AMERISCI JOB #:  
918121174

COMPANY: Forensic Analytical Consulting Services	ADDRESS: 2959 Pacific Commerce Drive, Rancho Dominguez 90221	P.O.#:
PROJECT INFORMATION	ANALYSIS TYPE	TURNAROUND TIME
		RUSH 24 HR 48 HR 72 HR 5 DAY OTHER
JOB NAME: Malibu H.S.	TEM AHERA <input checked="" type="checkbox"/>	MCE
JOB NUMBER: 7539974	PLM Bulk	PC
JOB MANAGER: Mark Smith	PCM Air	25 mm <input checked="" type="checkbox"/>
JOB DESCRIPTION: Air and Surface Sampling	PLM 1000 P.C.	37 mm
	Lead Air	0.45 um
	Lead Wipe	0.80 um
	Lead Paint / Soil	TEMP:
	OTHER:	OTHER: Roto # 10544

INITIAL RESULTS DELIVERY:  FAX  EMAIL  VERBAL  MAIL ONLY

REPORTS TO: Mark Smith

INVOICE TO:

COMMENTS:

RETURN SAMPLES YES

PHONE:

FAX:

EMAIL: msmith@forensicanalytical.com

CELL:

SAMPLE ID	SAMPLE LOCATION	START TIME	STOP TIME	TOTAL TIME X	LITERS /MIN.	TOTAL VOLUME	DATE COLLECTED
27	Clubhouse computer rm. NE	1335	1404	149	9.6	1430.4	
28	Clubhouse computer rm. office door	1340	1407	147	9.6	1411.2	
29	Clubhouse reception NW	1341	1408	147	9.6	1411.2	
30	Clubhouse Kitchen E. ctr.	1345	1411	146	9.6	1401.6	
31	Clubhouse Gams room NE	1347	1414	147	9.6	1411.2	
32	Clubhouse Chill room SE	1349	1415	146	9.6	1401.6	
33	Clubhouse NE office ctr.	1354	1419	145	9.6	1392.0	
34	Clubhouse SE office ctr.	1354	1420	144	9.6	1353.6	
35	Brents Club NE office ctr.	1359	1424	145	9.6	1392.0	
36	Brents Club Ltr. office ctr.	1400	1426	146	9.6	1401.6	
37	Brents Club SE office ctr.	1402	1427	145	9.6	1392.0	
B1	Blank						
B2	Blank						
B3	Blank						

SAMPLED BY:	DATE/TIME:	RECEIVED BY:	DATE/TIME:
RELINQUISHED BY:	DATE/TIME:	RECEIVED BY:	DATE/TIME:
RELINQUISHED BY:	DATE/TIME:	RECEIVED IN LAB BY:	DATE/TIME:

*[Handwritten signatures and dates: 12/02/18 19:00, 12/8/18 8:00]*



# Metals Analysis of HUD Wipes

(AIHA-LAP, LLC Accreditation, Lab ID #101629)

Forensic Analytical Consulting Svcs  
Mark A. Smith  
2959 Pacific Commerce Drive

Rancho Dominguez, CA 90221

**Client ID:** LA05  
**Report Number:** M205538  
**Date Received:** 12/05/18  
**Date Analyzed:** 12/05/18  
**Date Printed:** 12/05/18  
**First Reported:** 12/05/18

**Job ID / Site:** PJ39976; Malibu HS - Asb. Air Sampling & Lead Dust Surface Sampling 30215  
Morning View Drive Malibu CA 90265

**FALI Job ID:** LA05

**Date(s) Collected:** 12/4/18

**Total Samples Submitted:** 141

**Total Samples Analyzed:** 140

Sample Number	Lab Number	Area ft <sup>2</sup>	Analyte	Result	Result Units	Reporting Limit*	Method Reference
001	LM163180	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
002	LM163181	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
003	LM163182	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
004	LM163183	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
005	LM163184	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
006	LM163185	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
007	LM163186	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
008	LM163187	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
009	LM163188	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
010	LM163189	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
011	LM163190	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
012	LM163191	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
013	LM163192	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
014	LM163193	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
015	LM163194	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
016	LM163195	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
017	LM163196	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
018	LM163197	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
019	LM163198	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
020	LM163199	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
021	LM163200	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
022	LM163201	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
023	LM163202	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
024	LM163203	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
025	LM163204	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
026	LM163205	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082

# Metals Analysis of HUD Wipes

(AIHA-LAP, LLC Accreditation, Lab ID #101629)

Forensic Analytical Consulting Svcs  
Mark A. Smith  
2959 Pacific Commerce Drive

Rancho Dominguez, CA 90221

**Client ID:** LA05  
**Report Number:** M205538  
**Date Received:** 12/05/18  
**Date Analyzed:** 12/05/18  
**Date Printed:** 12/05/18  
**First Reported:** 12/05/18

**Job ID / Site:** PJ39976; Malibu HS - Asb. Air Sampling & Lead Dust Surface Sampling 30215  
Morning View Drive Malibu CA 90265

**FALI Job ID:** LA05

**Date(s) Collected:** 12/4/18

**Total Samples Submitted:** 141  
**Total Samples Analyzed:** 140

Sample Number	Lab Number	Area ft <sup>2</sup>	Analyte	Result	Result Units	Reporting Limit*	Method Reference
027	LM163206	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
028	LM163207	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
029	LM163208	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
030	LM163209	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
031	LM163210	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
032	LM163211	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
033	LM163212	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
034	LM163213	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
035	LM163214	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
036	LM163215	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
037	LM163216	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
038	LM163217	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
039	LM163218	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
040	LM163219	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
041	LM163220	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
042	LM163221	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
043	LM163222	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
044	LM163223	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
045	LM163224	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
046	LM163225	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
047	LM163226	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
048	LM163227	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
049	LM163228	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
050	LM163229	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
051	LM163230	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
052	LM163231	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082

# Metals Analysis of HUD Wipes

(AIHA-LAP, LLC Accreditation, Lab ID #101629)

Forensic Analytical Consulting Svcs  
Mark A. Smith  
2959 Pacific Commerce Drive

Rancho Dominguez, CA 90221

**Client ID:** LA05  
**Report Number:** M205538  
**Date Received:** 12/05/18  
**Date Analyzed:** 12/05/18  
**Date Printed:** 12/05/18  
**First Reported:** 12/05/18

**Job ID / Site:** PJ39976; Malibu HS - Asb. Air Sampling & Lead Dust Surface Sampling 30215  
Morning View Drive Malibu CA 90265

**FALI Job ID:** LA05

**Date(s) Collected:** 12/4/18

**Total Samples Submitted:** 141

**Total Samples Analyzed:** 140

Sample Number	Lab Number	Area ft <sup>2</sup>	Analyte	Result	Result Units	Reporting Limit*	Method Reference
053	LM163232	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
054	LM163233	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
055	LM163234	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
056	LM163235	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
057	LM163236	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
058	LM163237	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
059	LM163238	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
060	LM163239	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
061	LM163240	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
062	LM163241	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
063	LM163242	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
064	LM163243	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
065	LM163244	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
066	LM163245	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
067	LM163246	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
068	LM163247	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
069	LM163248	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
070	LM163249	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
071	LM163250	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
072	LM163251	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
074	LM163253	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
075	LM163254	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
076	LM163255	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
077	LM163256	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
078	LM163257	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
079	LM163258	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082

# Metals Analysis of HUD Wipes

(AIHA-LAP, LLC Accreditation, Lab ID #101629)

Forensic Analytical Consulting Svcs  
Mark A. Smith  
2959 Pacific Commerce Drive

Rancho Dominguez, CA 90221

**Client ID:** LA05  
**Report Number:** M205538  
**Date Received:** 12/05/18  
**Date Analyzed:** 12/05/18  
**Date Printed:** 12/05/18  
**First Reported:** 12/05/18

**Job ID / Site:** PJ39976; Malibu HS - Asb. Air Sampling & Lead Dust Surface Sampling 30215  
Morning View Drive Malibu CA 90265

**FALI Job ID:** LA05

**Date(s) Collected:** 12/4/18

**Total Samples Submitted:** 141

**Total Samples Analyzed:** 140

Sample Number	Lab Number	Area ft <sup>2</sup>	Analyte	Result	Result Units	Reporting Limit*	Method Reference
080	LM163259	1.00	Pb	9	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
081	LM163260	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
082	LM163261	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
083	LM163262	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
084	LM163263	1.00	Pb	8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
085	LM163264	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
086	LM163265	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
087	LM163266	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
088	LM163267	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
089	LM163268	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
090	LM163269	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
091	LM163270	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
092	LM163271	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
093	LM163272	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
094	LM163273	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
095	LM163274	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
096	LM163275	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
097	LM163276	1.00	Pb	10	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
098	LM163277	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
099	LM163278	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
100	LM163279	1.00	Pb	10	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
101	LM163280	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
102	LM163281	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
103	LM163282	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
104	LM163283	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
105	LM163284	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082

# Metals Analysis of HUD Wipes

(AIHA-LAP, LLC Accreditation, Lab ID #101629)

Forensic Analytical Consulting Svcs  
Mark A. Smith  
2959 Pacific Commerce Drive

Rancho Dominguez, CA 90221

**Client ID:** LA05  
**Report Number:** M205538  
**Date Received:** 12/05/18  
**Date Analyzed:** 12/05/18  
**Date Printed:** 12/05/18  
**First Reported:** 12/05/18

**Job ID / Site:** PJ39976; Malibu HS - Asb. Air Sampling & Lead Dust Surface Sampling 30215  
Morning View Drive Malibu CA 90265

**FALI Job ID:** LA05

**Date(s) Collected:** 12/4/18

**Total Samples Submitted:** 141  
**Total Samples Analyzed:** 140

Sample Number	Lab Number	Area ft <sup>2</sup>	Analyte	Result	Result Units	Reporting Limit*	Method Reference
106	LM163285	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
107	LM163286	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
108	LM163287	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
109	LM163288	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
110	LM163289	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
111	LM163290	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
112	LM163291	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
113	LM163292	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
114	LM163293	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
115	LM163294	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
116	LM163295	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
117	LM163296	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
118	LM163297	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
119	LM163298	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
120	LM163299	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
121	LM163300	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
122	LM163301	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
123	LM163302	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
124	LM163303	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
125	LM163304	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
126	LM163305	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
127	LM163306	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
128	LM163307	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
129	LM163308	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
130	LM163309	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
131	LM163310	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082



# Metals Analysis of HUD Wipes

(AIHA-LAP, LLC Accreditation, Lab ID #101629)

Forensic Analytical Consulting Svcs  
Mark A. Smith  
2959 Pacific Commerce Drive

Rancho Dominguez, CA 90221

**Client ID:** LA05  
**Report Number:** M205538  
**Date Received:** 12/05/18  
**Date Analyzed:** 12/05/18  
**Date Printed:** 12/05/18  
**First Reported:** 12/05/18

**Job ID / Site:** PJ39976; Malibu HS - Asb. Air Sampling & Lead Dust Surface Sampling 30215  
Morning View Drive Malibu CA 90265

**Date(s) Collected:** 12/4/18

**FALI Job ID:** LA05

**Total Samples Submitted:** 141

**Total Samples Analyzed:** 140

Sample Number	Lab Number	Area ft2	Analyte	Result	Result Units	Reporting Limit*	Method Reference
132	LM163311	1.00	Pb	< 8	ug/ft2	8	NIOSH 9100/7082
133	LM163312	1.00	Pb	< 8	ug/ft2	8	NIOSH 9100/7082
134	LM163313	1.00	Pb	< 8	ug/ft2	8	NIOSH 9100/7082
135	LM163314	1.00	Pb	< 8	ug/ft2	8	NIOSH 9100/7082
136	LM163315	1.00	Pb	< 8	ug/ft2	8	NIOSH 9100/7082
137	LM163316	1.00	Pb	9	ug/ft2	8	NIOSH 9100/7082
138	LM163317	1.00	Pb	< 8	ug/ft2	8	NIOSH 9100/7082
139	LM163318	1.00	Pb	< 8	ug/ft2	8	NIOSH 9100/7082
140	LM163319	1.00	Pb	< 8	ug/ft2	8	NIOSH 9100/7082
141	LM163320	1.00	Pb	< 8	ug/ft2	8	NIOSH 9100/7082

\* The Reporting Limit represents the lowest amount of analyte that the laboratory can confidently detect in the sample, and is not a regulatory level. The Units for the Reporting Limit are the same as the Units for the Final Results.

Beatriz Hinojosa, Laboratory Supervisor, Rancho Dominguez Laboratory

Analytical results and reports are generated by Forensic Analytical at the request of and for the exclusive use of the person or entity (client) named on such report. Results, reports or copies of same will not be released by Forensic Analytical to any third party without prior written request from client. This report applies only to the sample(s) tested. Supporting laboratory documentation is available upon request. This report must not be reproduced except in full, unless approved by Forensic Analytical. The client is solely responsible for the use and interpretation of test results and reports requested from Forensic Analytical. Forensic Analytical is not able to assess the degree of hazard resulting from materials analyzed. Forensic Analytical reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified. Any modifications that have been made to referenced test methods are documented in Forensic Analytical's Standard Operating Procedures Manual. Sample results have not been blank corrected. Quality control and sample receipt condition were acceptable unless otherwise noted.



# WIPE SAMPLE REQUEST FORM

8/16/18

Client: **LA05 FACS Los Angeles**  
 Santa Monica - Malibu Unified School District

Contact: **Mark Smith** Phone: **(310) 668-5600**

Site: **Malibu HS - Asb. Air Sampling & Lead Dust Surface Sampling**

Client No.: **C17288** FACS Job #: **PJ39976**

Sampled by: **D. Hong** PM: **Mark Smith** Date: **12/5/18**

Special Instructions: E-mail results to E-mail results to msmith@forensicanalytical.com and agarcia@forensicanalytical.com

Turnaround Time: 1-Day  2-Day  3-Day  5-Day  Other  **1 day**

Analysis:  Flame AA (Pb) **dust wipe**  Other:

Sample Number	Sample Location	Component	Area	Media/Lot#/Exp. Date	Result
001Pb	Rm 102 - Center	MA <del>table</del> Floor	1SF	Ghost Wipe 061318 EX7221	
002Pb	Rm 106 - N.E.	Floor			
003Pb	Rm 106 - W. Center	Table			
004Pb	Rm 105 - E.	Floor			
005Pb	Rm 103 - S.	Floor			
006Pb	Rm 103 - Center	Table			
007Pb	Rm 101-B - N	Floor			
008-Pb	Rm 101-A - N.E.	Floor			

Substrate: wood metal concrete plaster drywall brick

Shipped via:  Fed Ex  Airborne  UPS  US Mail  Courier  Drop Off  Other:

Relinquished by: *[Signature]* Date & Time: **12/4/18 20:50**

Received by: *[Signature]* Date & Time: **12/5/18 8AM D/C**

Condition Acceptable:  Yes  No

Condition Acceptable:  Yes  No



# WIPE SAMPLE REQUEST FORM

Client: LA05 FACS Los Angeles Santa Monica - Malibu Unified School District		Sampled by: <u>D. Hong</u> PM: <u>Mark Smith</u> Date: <u>12/18/18</u>	
Contact: <u>Mark Smith</u> Phone: (310) 668-5600		Special Instructions: E-mail results to E-mail results to msmith@forensicanalytical.com and agarcia@forensicanalytical.com	
Site: Malibu HS - Asb. Air Sampling & Lead Dust Surface Sampling	Turnaround Time: <input type="checkbox"/> 1-Day <input type="checkbox"/> 2-Day <input type="checkbox"/> 3-Day <input type="checkbox"/> 5-Day	Other: <input checked="" type="checkbox"/> <u>Flame AA (Pb) / dust wipe</u>	Due Date and Time:
Client No.: C17288	FACS Job #: PJ39976	Analysis: <input checked="" type="checkbox"/> Flame AA (Pb) / dust wipe <input type="checkbox"/> Other:	

Sample Number	Sample Location	Component	Area	Media/Lot#/Exp. Date	Result
009-Pb	Rm 101-A - W.	Table	1 SF	Ghost Wipe 061318 Ex 1221	
010-Pb	Teacher Lounge S.W.	Floor			
011-Pb	Rm 201 N.	Floor			
012-Pb	Rm 201 S.	Table			
013-Pb	Rm 200 S.	Floor			
014-Pb	Rm 202 Center	Floor			
015-Pb	Rm 202 E. Center	Table			
016-Pb	Rm 204 S.W.	Floor			

Shipped via:  Fed Ex  Airborne  UPS  US Mail  Courier  Drop Off  Other: \_\_\_\_\_

Relinquished by: [Signature] Date & Time: 12/18/18 20:50

Relinquished by: \_\_\_\_\_ Date & Time: \_\_\_\_\_

Received by: [Signature] Date & Time: 12/18/18 8:15 AM

Received by: \_\_\_\_\_ Date & Time: \_\_\_\_\_

Condition Acceptable:  Yes  No

Condition Acceptable:  Yes  No

Substrate: wood metal concrete plaster drywall brick





# WIPE SAMPLE REQUEST FORM

Client: <b>LA05 FACS Los Angeles</b> Santa Monica - Malibu Unified School District		Sampled by: <b>D. Hong</b> PM: <b>Mark Smith</b>		Date: <b>12/3/18</b>	
Contact: <b>Mark Smith</b> Phone: <b>(310) 668-5600</b>		Special Instructions: E-mail results to E-mail results to <a href="mailto:msmith@forensicanalytical.com">msmith@forensicanalytical.com</a> and <a href="mailto:agarcia@forensicanalytical.com">agarcia@forensicanalytical.com</a>			
Site: <b>Malibu HS - Asb. Air Sampling &amp; Lead Dust Surface Sampling</b>		Turnaround Time: <input type="checkbox"/> 1-Day <input type="checkbox"/> 2-Day <input type="checkbox"/> 3-Day <input type="checkbox"/> 5-Day	Other: <input checked="" type="checkbox"/> 10	Due Date and Time:	
Client No.: <b>C17288</b>		Analysis: <input checked="" type="checkbox"/> Flame AA (Pb) / dust wipe <input type="checkbox"/> Other:			

Sample Number	Sample Location	Component	Area	Media/Lot#/Exp. Date	Result
017-Pb	Rm-206 N.E., Floor	Floor	1 SF	ghost wipe 061318 EXP 1221	
018-Pb	Rm-206 N.W., Table	Table			
019-Pb	Rm-208 N.W., Floor	Floor			
020-Pb	Rm 210 Center, Floor	Floor			
021-Pb	Rm 210 W., Table	Table			
022-Pb	Rm 212 N.W., Floor	Floor			
023-Pb	Rm 203, S Floor	FLOOR			
024 Pb	Rm 203, E. Desk	DESK			

Shipped via:  Fed Ex  Airborne  UPS  US Mail  Courier  Drop Off  Other:

Substrate: wood metal concrete plaster drywall brick

Relinquished by: *[Signature]* Date & Time: **12/4/18 20:50**

Received by: *[Signature]* Date & Time: **12/5/18 8AM**

Condition Acceptable  Yes  No **D/D**

Relinquished by: *[Signature]* Date & Time: \_\_\_\_\_

Received by: \_\_\_\_\_ Date & Time: \_\_\_\_\_

Condition Acceptable  Yes  No

## WIPE SAMPLE REQUEST FORM

Client: LA05 FACS Los Angeles Santa Monica - Malibu Unified School District	Sampled by: D. Hong	PM: Mark Smith	Date: 12/3/18
Contact: Mark Smith Phone: (310) 668-5600	Special Instructions: E-mail results to E-mail results to msmith@forensicanalytical.com and agarcia@forensicanalytical.com		
Site: Malibu HS - Asb. Air Sampling & Lead Dust Surface Sampling	Turnaround Time: 1-Day <input type="checkbox"/> 2-Day <input type="checkbox"/> 3-Day <input type="checkbox"/> 5-Day <input type="checkbox"/> Other <input checked="" type="checkbox"/> Rush	Due Date and Time:	
Client No.: C17288	Analysis: <input checked="" type="checkbox"/> Flame AA (Pb) / DUST WIPE <input type="checkbox"/> Other:		

Sample Number	Sample Location	Component	Area	Media/Lot#/Exp. Date	Result
025 Pb	Rm 205 S FLOOR	FLOOR	1 ft <sup>2</sup>	Dustghost Wipe 061318 Exp. 1221	
026 Pb	Rm 207, N FLOOR	FLOOR			
027 Pb	Rm 207 NE DESK	DESK			
028 Pb	Rm 209 S FLOOR	FLOOR			
029 Pb	Rm 211, S FLOOR	FLOOR			
030 Pb	Rm 211, NE Podium	Podium			
031 Pb	Rm 303, CENTER FLOOR	FLOOR			
032 Pb	Rm 301, FLOOR SE Entrance	FLOOR			

Shipped via:  Fed Ex  Airborne  UPS  US Mail  Courier  Drop Off  Other:

Substrate: wood metal concrete plaster drywall brick

Relinquished by: *[Signature]* Date & Time: 12/4/18 20:50

Received by: *[Signature]* Date & Time: 12/5/18 8AM 12/0

Condition Acceptable:  Yes  No

Relinquished by: \_\_\_\_\_ Date & Time: \_\_\_\_\_

Received by: \_\_\_\_\_ Date & Time: \_\_\_\_\_

Condition Acceptable:  Yes  No



# WIPE SAMPLE REQUEST FORM

Client: LA05 FACS Los Angeles  
Santa Monica - Malibu Unified School District

Contact: Mark Smith Phone: (310) 668-5600

Site: Malibu HS - Asb. Air Sampling & Lead Dust Surface Sampling

Client No.: C17288 FACS Job #: PJ39976

Sampled by: D. Hong PM: Mark Smith Date: 12/29/18

Special Instructions: E-mail results to E-mail results to msmith@forensicanalytical.com and agarcia@forensicanalytical.com

Turnaround Time: 1-Day  2-Day  3-Day  5-Day  Other  Rush

Analysis:  Flame AA (Pb) / Dust wipe  Other:

Sample Number	Sample Location	Component	Area	Media/Lot#/Exp. Date	Result
033 Pb	Rm 301, N Counter	Counter	1 ft <sup>2</sup>	ghost wipe 061318 Exp 1221	
034 Pb	Rm 302, Center Floor	FLOOR			
035 Pb	Rm 401, Floor, S	FLOOR			
036 Pb	Rm 401, Counter, S	Counter			
037 Pb	Rm 402, Floor, Center	FLOOR			
038 Pb	Rm 500, Floor, SE	Floor			
039 Pb	Rm 500, Counter, N	Counter			
040 Pb.	Rm 501, Floor NE	FLOOR			

Shipped via:  Fed Ex  Airborne  UPS  US Mail  Courier  Drop Off  Other:

Substrate: wood metal concrete plaster drywall brick

Relinquished by: *[Signature]* Date & Time: 12/4/18 20:50

Received by: *[Signature]* Date & Time: 12/5/18 8am MD

Condition Acceptable:  Yes  No



# WIPE SAMPLE REQUEST FORM

Client: **LA05 FACS Los Angeles**  
 Santa Monica - Malibu Unified School District

Contact: **Mark Smith** Phone: **(310) 668-5600**

Site: **Malibu HS - Asb. Air Sampling & Lead Dust Surface Sampling**

Client No.: **C17288** FACS Job #: **PJ39976**

Sampled by: **D. Hong** PM: **Mark Smith** Date: **12/18/18**

Special Instructions: E-mail results to E-mail results to msmith@forensicanalytical.com and agarcia@forensicanalytical.com

Turnaround Time: 1-Day  2-Day  3-Day  5-Day  Other:  **DUST**

Analysis:  Flame AA (Pb) / **Dust wipe** Other:

Sample Number	Sample Location	Component	Area	Media/Lot#/Exp. Date	Result
0404 Pb	Rm 502 FLOOR, E	FLOOR	1 ft <sup>2</sup>	ghost wipe 061318 EXP.1221	
042 Pb	Rm 502 DESK, S	DESK			
043 Pb	Rm 511 ADMIN, FLOOR	FLOOR			
044 Pb	VP#1, SE OFFICE FLOOR	FLOOR			
045 Pb	VP#2 SE OFF. DESK	DESK			
046 Pb	VP#2 S OFF. FLOOR	FLOOR			
047 Pb	PRINCIPAL FLOOR	FLOOR			
048 Pb	PRINCIPAL DESK	DESK			

Shipped via:  Fed Ex  Airborne  UPS  US Mail  Courier  Drop Off  Other: \_\_\_\_\_

Substrate: wood metal concrete plaster drywall brick

Relinquished by: *[Signature]* Date & Time: **12/18/18 20:50**

Received by: *[Signature]* Date & Time: **12/15/18 8 AM**

Condition Acceptable:  Yes  No

Relinquished by: \_\_\_\_\_ Date & Time: \_\_\_\_\_

Received by: \_\_\_\_\_ Date & Time: \_\_\_\_\_

Condition Acceptable:  Yes  No



# WIPE SAMPLE REQUEST FORM

Client: **LA05 FACS Los Angeles**  
 Santa Monica - Malibu Unified School District

Contact: **Mark Smith** Phone: (310) 668-5600

Sampled by: **D. Hong** PM: **Mark Smith** Date: **12/4/18**

Special Instructions: E-mail results to E-mail results to msmith@forensicanalytical.com and agarcia@forensicanalytical.com

Site: **Malibu HS - Asb. Air Sampling & Lead Dust Surface Sampling**

Client No.: **C17288** FACS Job #: **PJ39976**

Turnaround Time: 1-Day  2-Day  3-Day  5-Day  Other:  Rush

Analysis:  Flame AA (Pb) / dust wipe  Other:

Sample Number	Sample Location	Component	Area	Media/Lot#/Exp. Date	Result
049 Pb	Rm 511 Conf. Rm Floor	FLOOR	1 ft <sup>2</sup>	ghost wipe 061318 Exp. 1221	
050 Pb	Rm 512 - Atn + Copying. Floor	FLOOR			
051 Pb	Atn + Copying. file cabinet	File cabinet			
052 Pb	office #1 Floor	FLOOR			
053 Pb	office #2 Floor	FLOOR			
054 Pb	office #2 Desk	DESK			
055 Pb	office #3 Floor	FLOOR			
056 Pb	office #4 Floor	FLOOR			

Shipped via:  Fed Ex  Airborne  UPS  US Mail  Courier  Drop Off  Other:

Substrate: wood metal concrete plaster drywall brick

Relinquished by: *[Signature]* Date & Time: **12/4/18 20:50**

Received by: *[Signature]* Date & Time: **12/5/18 8AM D70**

Condition Acceptable:  Yes  No

Relinquished by: *[Signature]* Date & Time: \_\_\_\_\_

Received by: \_\_\_\_\_ Date & Time: \_\_\_\_\_

Condition Acceptable:  Yes  No



# WIPE SAMPLE REQUEST FORM

Client: **LA05 FACS Los Angeles**  
 Santa Monica - Malibu Unified School District

Contact: **Mark Smith** Phone: (310) 668-5600

Sampled by: **D. Hong** PM: **Mark Smith** Date: **12/4/18**

Special Instructions: E-mail results to E-mail results to msmith@forensicanalytical.com and agarcia@forensicanalytical.com

Turnaround Time: 1-Day  2-Day  3-Day  5-Day  Other  **1 hr**

Analysis:  Flame AA (Pb) / **dust wipe**  Other:

Sample Number	Sample Location	Component	Area	Media/Lot#/Exp. Date	Result
057 Pb	Rm 512 office #4	DESK	1 ft <sup>2</sup>	ghost wipe 061318 Exp. 1221	
058 Pb	Rm 513 Nurse Main	FLOOR			
059 Pb	Nurse office	FLOOR			
060 Pb	↓ File cab	File cabinet			
061 Pb	FIRST AID Rm, FLOOR	FLOOR			
062 Pb	Exam Rm, FLOOR	FLOOR			
063 Pb	Exam Rm, counter	FLOOR Ⓜ Counter FLOOR			
064 Pb	↓ Liason office, FLOOR	FLOOR			

Shipped via:  Fed Ex  Airborne  UPS  US Mail  Courier  Drop Off  Other:

Substrate: wood metal concrete plaster drywall brick

Relinquished by: *[Signature]* Date & Time: **12/4/18 20:50**

Received by: *[Signature]* Date & Time: **12/5/18 8 AM**

Condition Acceptable:  Yes  No

Relinquished by: \_\_\_\_\_ Date & Time: \_\_\_\_\_

Received by: \_\_\_\_\_ Date & Time: \_\_\_\_\_

Condition Acceptable:  Yes  No

**WIPE SAMPLE REQUEST FORM**

Client: **LA05 FACS Los Angeles Santa Monica - Malibu Unified School District**  
 Sampled by: **D. Hong** PM: **Mark Smith** Date: **12/4/18**

Contact: **Mark Smith** Phone: **(310) 668-5600**  
 Special Instructions: E-mail results to E-mail results to msmith@forensicanalytical.com and agarcia@forensicanalytical.com

Site: **Malibu HS - Asb. Air Sampling & Lead Dust Surface Sampling**  
 Turnaround Time: 1-Day  2-Day  3-Day  5-Day  Other  Rush

Client No.: **C17288** FACS Job #: **PJ39976**  
 Analysis:  Flame AA (Pb) / dust wipe  Other:

Sample Number	Sample Location	Component	Area	Media/Lot#/Exp. Date	Result
065 Pb	Rm 513 liaison off. Floor	FLOOR	1 SF	ghost wipe 061318 exp. 1221	
066 Pb	↓ , DESK	DESK			
067 Pb	Rm 601 floor, center	FLOOR			
068 Pb	Rm 603 FLOOR, SW	FLOOR			
069 Pb	Rm 603 DESK, EN	DESK			
070 Pb	Rm 606 FLOOR, E	FLOOR			
071 Pb	Rm 605 FLOOR, W	FLOOR			
072 Pb	Rm 605 DESK, N	DESK			

Shipped via:  Fed Ex  Airborne  UPS  US Mail  Courier  Drop Off  Other:

Substrate: wood metal concrete plaster drywall brick

Relinquished by: *[Signature]* Date & Time: **12/4/18 20:00**  
 Received by: *[Signature]* Date & Time: **12/5/18 8 AM**

Condition Acceptable  Yes  No

Relinquished by: \_\_\_\_\_ Date & Time: \_\_\_\_\_  
 Received by: \_\_\_\_\_ Date & Time: \_\_\_\_\_  
 Condition Acceptable  Yes  No



# WIPE SAMPLE REQUEST FORM

Client: LA05 FACS Los Angeles Santa Monica - Malibu Unified School District		Sampled by: D. Hong		PM: Mark Smith		Date: 12/4/18	
Contact: Mark Smith Phone: (310) 668-5600		Special Instructions: E-mail results to E-mail results to msmith@forensicanalytical.com and agarcia@forensicanalytical.com					
Site: Malibu HS - Asb. Air Sampling & Lead Dust Surface Sampling		Turnaround Time:		1-Day <input type="checkbox"/>		2-Day <input type="checkbox"/>	
Client No.: C17288		Analysis: <input checked="" type="checkbox"/> Flame AA (Pb) / Dust wipe		3-Day <input type="checkbox"/>		5-Day <input type="checkbox"/>	
FACS Job #: PJ39976		Other: <input type="checkbox"/>		Other: <input checked="" type="checkbox"/> 1 gm		Due Date and Time:	

Sample Number	Sample Location	Component	Area	Media/Lot#/Exp. Date	Result
073 Pb	Rm 604, Floor	Floor	1A2	ghost wipe 061318 EX1221	
074 Pb	Rm 602, Floor SW	Floor			
075 Pb	Rm 602, DESK S	DESK			
076 Pb	Rm 621, Floor, SW	Floor			
077 Pb	Rm 622, Floor, E	Floor			
078 Pb	Rm 622, DESK, center	DESK			
079 Pb	Rm 623, Floor, NW	FLOOR			
080 Pb.	Rm 626, Floor, E	Floor			

Substrate: wood metal concrete plaster drywall brick

Shipped via:  Fed Ex  Airborne  UPS  US Mail  Courier  Drop Off  Other:

Relinquished by: *[Signature]* Date & Time: 12/18/18 20:50

Received by: *[Signature]* Date & Time: 12/5/18 8AM 2018

Condition Acceptable:  Yes  No

Relinquished by: *[Signature]* Date & Time: Condition Acceptable:  Yes  No





# WIPE SAMPLE REQUEST FORM

Client: **LA05 FACS Los Angeles**  
 Santa Monica - Malibu Unified School District

Contact: **Mark Smith** Phone: **(310) 668-5600**

Sampled by: **D. Hong** PM: **Mark Smith** Date: **12/4/18**

Special Instructions: E-mail results to E-mail results to [msmith@forensicanalytical.com](mailto:msmith@forensicanalytical.com) and [agarcia@forensicanalytical.com](mailto:agarcia@forensicanalytical.com)

Site: **Malibu HS - Asb. Air Sampling & Lead Dust Surface Sampling**

Client No.: **C17288** FACS Job #: **PJ39976**

Turnaround Time: 1-Day  2-Day  3-Day  5-Day  Other  **1 wsh**

Analysis:  Flame AA (Pb) / **Dust wipe**  Other:

Sample Number	Sample Location	Component	Area	Media/Lot#/Exp. Date	Result
081 Pb	Rm 626, Counter, W	Counter	1 SF	Ghost wipe 061318 Exp. 1221	
082 Pb	Rm 625, FLOOR, Center	FLOOR <del>Center</del> <b>Ⓚ</b>			
083 Pb	Rm 624, FLOOR, S.	FLOOR			
084 Pb	Rm 624, DESK, S	DESK			
085 Pb	Kitchen, Floor, S	FLOOR			
086 Pb	<del>Kitchen</del> Auditorium, Floor, West	FLOOR			
087 Pb	Auditorium, Floor, S	FLOOR			
088 Pb	Serving Area, Floor, E	FLOOR			

Shipped via:  Fed Ex  Airborne  UPS  US Mail  Courier  Drop Off  Other:

Relinquished by: Date & Time: **12/4/18 20:50**

Received by: Date & Time: **12/5/18 8AM**

Condition Acceptable:  Yes  No

Relinquished by: Date & Time: **12/4/18 20:50**

Received by: Date & Time: **12/5/18 8AM**

Condition Acceptable:  Yes  No

Substrate: wood metal concrete plaster drywall brick



# WIPE SAMPLE REQUEST FORM

Client: LA05 FACS Los Angeles Santa Monica - Malibu Unified School District		Sampled by: Deeta Hong		PM: Mark Smith	Date: 12/4/18
Contact: Mark Smith Phone: (310) 668-5600		Special Instructions: E-mail results to E-mail results to msmith@forensicanalytical.com and agarcia@forensicanalytical.com			
Site: Malibu HS - Asb. Air Sampling & Lead Dust Surface Sampling	Turnaround Time: <input type="checkbox"/> 1-Day <input type="checkbox"/> 2-Day <input type="checkbox"/> 3-Day <input type="checkbox"/> 5-Day	Other: <input checked="" type="checkbox"/> 10A	Due Date and Time:		
Client No.: C17288	FACS Job #: PJ39976	Analysis: <input checked="" type="checkbox"/> Flame AA (Pb) / dust wipe			

Sample Number	Sample Location	Component	Area	Media/Lot#/Exp. Date	Result
089Pb	Rm 104, Floor	Floor	ISF	Ghost wipe 261318, EXP 1221	
090Pb	Rm 104, Counter, W	Counter			
091Pb	New Gym, Floor, S	Floor			
092Pb	Director's office, Floor, W	Floor			
093Pb	Director's office, Desk, center	Desk			
094Pb	Gym (main) Floor, center	Floor			
095Pb	Independent study, Floor, SW.	Floor			
096Pb	Independent study, desk, W.	Desk			

Substrate: wood metal concrete plaster drywall brick

Shipped via:  Fed Ex  Airborne  UPS  US Mail  Courier  Drop Off  Other:

Relinquished by: *[Signature]* Date & Time: 12/4/18 20:50

Received by: *[Signature]* Date & Time: 12/5/18 8 AM

Condition Acceptable:  Yes  No

Relinquished by: *[Signature]* Date & Time:  Yes  No

Received by: *[Signature]* Date & Time:  Yes  No



# WIPE SAMPLE REQUEST FORM

Client: LA05 FACS Los Angeles Santa Monica - Malibu Unified School District		Sampled by: D. Hong		PM: Mark Smith		Date: 12/4/18	
Contact: Mark Smith Phone: (310) 668-5600		Special Instructions: E-mail results to E-mail results to msmith@forensicanalytical.com and agarcia@forensicanalytical.com					
Site: Malibu HS - Asb. Air Sampling & Lead Dust Surface Sampling		Turnaround Time:	1-Day <input type="checkbox"/>	2-Day <input type="checkbox"/>	3-Day <input type="checkbox"/>	5-Day <input type="checkbox"/>	Other: <input checked="" type="checkbox"/> 1 wk
Client No.: C17288		Analysis: <input checked="" type="checkbox"/> Flame AA (Pb) / dust wipe <input type="checkbox"/> Other:					
FACS Job #: PJ39976							

Sample Number	Sample Location	Component	Area	Media/Lot#/Exp. Date	Result
097Pb	Weight Rm, Floor, N.W	Floor	1SF	ghost wipe 061318 EXP.1221	
098Pb	Girl's Coach Office, Floor, N.W	Floor			
099Pb	Girl's Coach Office, Desk, Center	Desk			
100Pb	Girl's lockers, Floor, Center	Floor			
101Pb	Boy's lockers, Floor, S.	Floor			
102Pb	Boy's lockers, Locker, W.	Locker			
103Pb	Boy's Coach Office, Floor, W	Floor			
104Pb	Rm 723, Floor, S.	Floor			

Substrate: wood metal concrete plaster drywall brick

Shipped via:  Fed Ex  Airborne  UPS  US Mail  Courier  Drop Off  Other:

Relinquished by: *[Signature]* Date & Time: 12/4/18 20:50

Received by: *[Signature]* Date & Time: 12/5/18 8Am

Condition Acceptable:  Yes  No

Relinquished by: *[Signature]* Date & Time: *[Blank]*

Received by: *[Blank]* Date & Time: *[Blank]*

Condition Acceptable:  Yes  No

**WIPE SAMPLE REQUEST FORM**

Client: <b>LA05 FACS Los Angeles</b> Santa Monica - Malibu Unified School District	Sampled by: <b>D. Hong</b>	PM: <b>Mark Smith</b>	Date: <b>12/3/18</b>
Contact: <b>Mark Smith</b> Phone: <b>(310) 668-5600</b>	Special Instructions: E-mail results to E-mail results to msmith@forensicanalytical.com and agarcia@forensicanalytical.com		
Site: <b>Malibu HS - Asb. Air Sampling &amp; Lead Dust Surface Sampling</b>	Turnaround Time:	1-Day <input type="checkbox"/>	2-Day <input type="checkbox"/>
Client No.: <b>C17288</b>	Analysis:	3-Day <input type="checkbox"/>	5-Day <input type="checkbox"/>
FACS Job #: <b>PJ39976</b>	Other:	Other <input checked="" type="checkbox"/> 19h	Due Date and Time:
Flame AA (Pb) / dust wipe		Wipe	

Sample Number	Sample Location	Component	Area	Media/Lot#/Exp. Date	Result
105Pb	Rm 723, Desk, N.	Desk	1SF	Ghost wipe 061318 exp 1221	
106Pb	Rm 505, Floor, Center	Floor			
107Pb	Rm 506, Floor, N.	Floor			
108Pb	Rm 506, Table, Center	Table			
109Pb	Library, Floor, Center	Floor			
110Pb	Rm P4, Floor, Center	Floor			
111Pb	Rm P4, Desk, E.	Desk			
112Pb	Rm P3, Floor, W.	Floor			

Substrate: wood metal concrete plaster drywall brick

Shipped via:  Fed Ex  Airborne  UPS  US Mail  Courier  Drop Off  Other:

Relinquished by: *[Signature]* Date & Time: **12/18/18 20:58**

Received by: *[Signature]* Date & Time: **12/5/18 8 Am D10**

Condition Acceptable:  Yes  No

Relinquished by: *[Signature]* Date & Time: \_\_\_\_\_

Received by: \_\_\_\_\_ Date & Time: \_\_\_\_\_

Condition Acceptable:  Yes  No



# WIPE SAMPLE REQUEST FORM

Client: LA05 FACS Los Angeles Santa Monica - Malibu Unified School District		Sampled by: D. Hong		PM: Mark Smith		Date: 12/4/18	
Contact: Mark Smith Phone: (310) 668-5600		Special Instructions: E-mail results to E-mail results to msmith@forensicanalytical.com and agarcia@forensicanalytical.com					
Site: Malibu HS - Asb. Air Sampling & Lead Dust Surface Sampling		Turnaround Time:	1-Day <input type="checkbox"/>	2-Day <input type="checkbox"/>	3-Day <input type="checkbox"/>	5-Day <input type="checkbox"/>	Other <input checked="" type="checkbox"/> Yes
Client No.: C17288		Analysis: <input checked="" type="checkbox"/> Flame AA (Pb) / dust wipe <input type="checkbox"/> Other:					
FACS Job #: PJ39976							

Sample Number	Sample Location	Component	Area	Media/Lot#/Exp. Date	Result
113Pb	Rm P2, Floor, E.	Floor	1SF	ghost wipe 061312 Exp 1221	
114Pb	Rm P2, Table, S.	Table			
115Pb	Rm P9, Floor, E.	Floor			
116Pb	Rm P8, Floor, Center	Floor			
117Pb	Rm P8, Table, S.E.	Table			
118Pb	Rm P7, Floor, Center	Floor			
119Pb	Rm P6, Floor, E.	Floor			
120Pb	Rm P6, Desk, N.E.	Desk			

Substrate: wood metal concrete plaster drywall brick

Shipped via:  Fed Ex  Airborne  UPS  US Mail  Courier  Drop Off  Other:

Relinquished by: *[Signature]* Date & Time: 12/4/18 20:50

Received by: *[Signature]* Date & Time: 12/5/18 8am D10

Condition Acceptable:  Yes  No

Relinquished by: \_\_\_\_\_ Date & Time: \_\_\_\_\_

Received by: \_\_\_\_\_ Date & Time: \_\_\_\_\_

Condition Acceptable:  Yes  No

WIPE SAMPLE REQUEST FORM

Client: **LADS FACS Los Angeles Santa Monica - Malibu Unified School District**  
 Contact: **MARK SMITH** Phone: **(310)668-5600**  
 Site: **Malibu H.S. - Asb. Air Sampling + Lead Dust Surfaces Sampling**  
 Client No.: **C17288** Job #: **PJ39976**  
 Sampled by: **D. Hong** PM: **MARK SMITH** Date: **12/4/18**  
 Special Instructions: **Email results to: msmith@forensicanalytical.com**  
 Turnaround Time: 1-Day  2-Day  3-Day  5-Day  Other:  Wipe  
 Analysis:  Flame AA (Pb) / **dust wipe** Other:

Sample Number	Sample Location	Component	Area	Media/Lot#/Exp. Date	Result
121 Pb	Rm P5, Floor, N.	Floor	ISP	ghost wipe 060318 EXP1221	
122 Pb	B46 Club, lobby, Floor, S.E.	Floor			
123 Pb	B46 Club, lobby, Counter, S.	Counter			
124 Pb	B46 Club, N. Office,	Floor			
125 Pb	B46 Club, Computer Rm, S.	Floor			
126 Pb	B46 Club, Computer Rm, W.	Table			
127 Pb	B46 Club, S. Office, Floor, Center	Floor			
128 Pb	B46 Club, Game Room, E. Center	Floor			

Substrate: wood metal concrete plaster drywall brick

Shipped via:  Fed Ex  Airborne  UPS  US Mail  Courier  Drop Off  Other:

Relinquished by: *[Signature]* Date & Time: **12/4/18 20:50**  
 Received by: *[Signature]* Date & Time: **12/5/18 5 AM 12/10**  
 Condition Acceptable:  Yes  No  
 Relinquished by: *[Signature]* Date & Time: **12/4/18 20:50**  
 Received by: *[Signature]* Date & Time: **12/5/18 5 AM 12/10**  
 Condition Acceptable:  Yes  No

**WIPE SAMPLE REQUEST FORM**

Client: **LA05 FACs Los Angeles Santa Monica - Malibu Unified School District** Sampled by: **D. Hong** PM: **MARK SMITH** Date: **12/4/18**

Contact: **MARK SMITH** Phone: **(310) 668-5600** Special Instructions: **Please email results to: msmith@forensicanalytical.com**

Site: **Madibu H.S. - ASB - Air Sampling & lead dust surfaces sampling** Turnaround Time: 1-Day  2-Day  3-Day  5-Day  Other  **ngh** Due Date and Time:

Client No.: **C17288** Analysis:  **Flame AA (Pb)** / **dust wipe** Other:

FACS Job #: **PJ39976**

Sample Number	Sample Location	Component	Area	Media/Lot#/Exp. Date	Result
129Pb	B46 club Game Rm, Table, W. Center	Table	1SF	Ghost wipe 061318 Exp 1221	
130Pb	B46 club Kitchen, N.	Floor			
131Pb	B46 club, office 1, Floor, W.	Floor			
132Pb	B46 club, office 1, Desk, E	Desk			
133Pb	B46 club, office 2, Floor, W	Floor			
134Pb	B46 club, office 3, Floor, N.	Floor			
135Pb	B46 club, office 3, Desk, W.	Desk			
136Pb	B46 club, office 4, Floor, Center	Floor			

Substrate: wood metal concrete plaster drywall brick

Shipped via:  Fed Ex  Airborne  UPS  US Mail  Courier  Drop Off  Other:

Requiring seal by: *[Signature]* Date & Time: **12/18/18 2:50**

Received by: *[Signature]* Date & Time: **12/5/18 8am 10/0**

Condition Acceptable:  Yes  No

Received by: \_\_\_\_\_ Date & Time: \_\_\_\_\_

Condition Acceptable:  Yes  No

WIPE SAMPLE REQUEST FORM

Client: **LABS EFACS Los Angeles**  
**SANTA MONICA - Malibu Unified School District**

Contact: **MARK SMITH** Phone: **(310) 668-5600**

Site: **Malibu H.S. - Asb. Air Sampling & Lead dust**  
**Surfaces Sampling**

Client No.: **C17288** FACS Job #: **PJ39974**

Sampled by: **D. Hong** PM: **Mark Smith** Date: **12/4/18**

Special Instructions: **Please email results to msmith@forensicanalytical.com**

Turnaround Time: 1-Day  2-Day  3-Day  5-Day  Other  **rush**

Analysis:  **Flame AA (Pb)** / **dust wipe**  
 Other:

Sample Number	Sample Location	Component	Area	Media/Lot#/Exp. Date	Result
137Pb	B&G club, office B, Floor, Center	Floor	1SF ↓	ghost wipe 061318 EXP1221	
138Pb	B&G club, office B, Desk, W	Desk			
139Pb	BLANK				
140Pb	BLANK				
141Pb	BLANK				
<b>DI</b>					

Substrate: wood metal concrete plaster drywall brick

Shipped via:  Fed Ex  Airborne  UPS  US Mail  Courier  Drop Off  Other:

Relinquished by: *[Signature]* Date & Time: **12/4/18 20:50**

Received by: *[Signature]* Date & Time: **12/15/18 8AM NO**

Condition Acceptable  Yes  No

Relinquished by: *[Signature]* Date & Time: **12/4/18 20:50**

Received by: *[Signature]* Date & Time: **12/15/18 8AM NO**

Condition Acceptable  Yes  No





# Metals Analysis of HUD Wipes

(AIHA-LAP, LLC Accreditation, Lab ID #101629)

Forensic Analytical Consulting Svcs  
Mark A. Smith  
2959 Pacific Commerce Drive

Rancho Dominguez, CA 90221

**Client ID:** LA05  
**Report Number:** M205716  
**Date Received:** 12/08/18  
**Date Analyzed:** 12/10/18  
**Date Printed:** 12/10/18  
**First Reported:** 12/10/18

**Job ID / Site:** PJ39976; Malibu HS - Asb. Air Sampling & Lead Dust Surface Sampling 30215  
Morning View Drive Malibu CA 90265

**Date(s) Collected:** 12/07/18

**FALI Job ID:** LA05

**Total Samples Submitted:** 2

**Total Samples Analyzed:** 2

Sample Number	Lab Number	Area ft <sup>2</sup>	Analyte	Result	Result Units	Reporting Limit*	Method Reference
142PB	LM163464	1.00	Pb	< 8	ug/ft <sup>2</sup>	8	NIOSH 9100/7082
143PB	LM163465		Pb	< 8	ug	8	NIOSH 9100/7082

\* The Reporting Limit represents the lowest amount of analyte that the laboratory can confidently detect in the sample, and is not a regulatory level. The Units for the Reporting Limit are the same as the Units for the Final Results.

Beatriz Hinojosa, Laboratory Supervisor, Rancho Dominguez Laboratory

Analytical results and reports are generated by Forensic Analytical at the request of and for the exclusive use of the person or entity (client) named on such report. Results, reports or copies of same will not be released by Forensic Analytical to any third party without prior written request from client. This report applies only to the sample(s) tested. Supporting laboratory documentation is available upon request. This report must not be reproduced except in full, unless approved by Forensic Analytical. The client is solely responsible for the use and interpretation of test results and reports requested from Forensic Analytical. Forensic Analytical is not able to assess the degree of hazard resulting from materials analyzed. Forensic Analytical reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified. Any modifications that have been made to referenced test methods are documented in Forensic Analytical's Standard Operating Procedures Manual. Sample results have not been blank corrected. Quality control and sample receipt condition were acceptable unless otherwise noted.



# WIPE SAMPLE REQUEST FORM

<b>Client:</b> LA05 FACS Los Angeles Santa Monica - Malibu Unified School District	<b>Sampled by:</b> RDM	<b>PM:</b> Mark Smith	<b>Date:</b> 12/07/18
<b>Contact:</b> Mark Smith Phone: (310) 668-5600	<b>Special Instructions:</b> E-mail results to E-mail results to msmith@forensicanalytical.com and agarcia@forensicanalytical.com		
<b>Site:</b> Malibu HS - Asb. Air Sampling & Lead Dust Surface Sampling	<b>Turnaround Time:</b>	1-Day <input checked="" type="checkbox"/> 2-Day <input type="checkbox"/> 3-Day <input type="checkbox"/> 5-Day <input type="checkbox"/> Other <input type="checkbox"/>	<b>Due Date and Time:</b>
<b>Client No.:</b> C17288	<b>FACS Job #:</b> PJ39976	<b>Analysis:</b> <input checked="" type="checkbox"/> Flame AA (Pb) / <input type="checkbox"/> Other:	

Sample Number	Sample Location	Component	Area	Media/Lot#/Exp. Date	Result
142 Pb	ROOM H604, FLOOR (CARPET)	FLOOR	12" x 12"	0708 072110 EXP 10-19	
143 Pb	BLANK				

Shipped via:  Fed Ex  Airborne  UPS  US Mail  Courier  Drop Off  Other:

Substrate: wood metal concrete plaster drywall brick

Relinquished by: *[Signature]* Date & Time: 12/07/18 1515  
 Received by: *[Signature]* Date & Time: 12/07/18 1520  
 Condition Acceptable  Yes  No

Relinquished by: *[Signature]* Date & Time: 12/07/18 1912  
 Received by: *[Signature]* Date & Time: 12-08-18  
 Condition Acceptable  Yes  No

## LEAD HAZARD EVALUATION REPORT

**Section 1 — Date of Lead Hazard Evaluation** 12/04/18 & 12/07/18

**Section 2 — Type of Lead Hazard Evaluation (Check one box only)**

Lead Inspection     Risk assessment     Clearance Inspection     Other (specify) Surface sampling

**Section 3 — Structure Where Lead Hazard Evaluation Was Conducted**

Address [number, street, apartment (if applicable)] <b>30215 Morning View Drive</b>		City <b>Malibu</b>	County <b>Los Angeles</b>	Zip Code <b>90265</b>
Construction date (year) of structure <b>Unknown</b>	Type of structure <input type="checkbox"/> Multi-unit building <input checked="" type="checkbox"/> School or daycare <input type="checkbox"/> Single family dwelling <input type="checkbox"/> Other _____		Children living in structure? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Don't Know	


**Section 4 — Owner of Structure (if business/agency, list contact person)**

Name <b>Santa Monica-Malibu Unified School District ( Project Contact: Carey Upton)</b>		Telephone number <b>310-399-5865 x79383</b>		
Address [number, street, apartment (if applicable)] <b>1651 16th Street</b>		City <b>Santa Monica</b>	State <b>California</b>	Zip Code <b>90404</b>

**Section 5 — Results of Lead Hazard Evaluation (check all that apply)**

No lead-based paint detected     Intact lead-based paint detected     Deteriorated lead-based paint detected  
 No lead hazards detected     Lead-contaminated dust found     Lead-contaminated soil found     Other \_\_\_\_\_

**Section 6 — Individual Conducting Lead Hazard Evaluation**

Name <b>Robert McWhorter</b>		Telephone number <b>310-668-5600</b>		
Address [number, street, apartment (if applicable)] <b>Forensic Analytical - 2959 Pacific Commerce Drive</b>		City <b>Rancho Dominguez</b>	State <b>California</b>	Zip Code <b>90221</b>
CDPH certification number <b>4944</b>	Signature 			Date <b>12/21/18</b>

Name and CDPH certification number of any other individuals conducting sampling or testing (if applicable)

**Deeta Hong - No. 28714**

**Section 7 — Attachments**

- A. A foundation diagram or sketch of the structure indicating the specific locations of each lead hazard or presence of lead-based paint;
- B. Each testing method, device, and sampling procedure used;
- C. All data collected, including quality control data, laboratory results, including laboratory name, address, and phone number.

First copy and attachments retained by inspector  
 Second copy and attachments retained by owner

Third copy only (no attachments) mailed or faxed to:  
 California Department of Public Health  
 Childhood Lead Poisoning Prevention Branch Reports  
 850 Marina Bay Parkway, Building P, Third Floor  
 Richmond, CA 94804-6403  
 Fax: (510) 620-5656